



# 中国节能产品认证证书

证书编号：CQC19701220546

申请人名称及地址：伊顿电源（上海）有限公司  
中国（上海）自由贸易试验区日滨路76号B5部位

品 牌：EATON

制造商名称及地址：山特电子（深圳）有限公司  
深圳市宝安区72区宝石路8号

生产企业名称及地址：山特电子（深圳）有限公司  
深圳市宝安区72区宝石路8号

产 品 名 称：不间断电源

系 列/规 格/型 号：见附件

认 证 模 式：产品检验+初始工厂检查+获证后监督

产品标准/技术要求：CQC3108-2011

上述产品符合 CQC31-461234-2009 认证规则的要求，特此发证。

证书有效期：2019年06月03日至2024年06月03日  
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。



主任：

陆梅



## 中国质量认证中心



# 中国节能产品认证证书

附 录

第 1 页 共 1 页

证书编号: CQC19701220546

纸 号: 144897

型号	交流输入	逆变输出	系统容量	外形尺寸 (mm)
93PS-10(10)-0-M BS	AC380V, 3W+N+PE, 50/60Hz, 19A	AC380V, 3W+N+PE, 50/60Hz, 15A	10kVA/10KW	750*335*1300
93PS-10(10)-1x9 Ah-MBS	AC380V, 3W+N+PE, 50/60Hz, 19A	AC380V, 3W+N+PE, 50/60Hz, 15A	10kVA/10KW	750*335*1300
93PS 15kVA	AC380V, 3W+N+PE, 50/60Hz, 29A	AC380V, 3W+N+PE, 50/60Hz, 23A	15kVA/15KW	750*335*1300
93PS 20kVA	AC380V, 3W+N+PE, 50/60Hz, 38A	AC380V, 3W+N+PE, 50/60Hz, 30A	20kVA/20KW	750*335*1300
93PS 30kVA	AC380V, 3W+N+PE, 50/60Hz, 57A	AC380V, 3W+N+PE, 50/60Hz, 46A	30kVA/30KW	750*480*1750
93PS 40kVA	AC380V, 3W+N+PE, 50/60Hz, 76A	AC380V, 3W+N+PE, 50/60Hz, 61A	40kVA/40KW	750*480*1750

注: 此附录与证书同时使用时有效。



主任:

陆梅



## 中国质量认证中心



# CHINA CERTIFICATE FOR ENERGY CONSERVATION PRODUCT

CERTIFICATE NO.: CQC19701220546

NAME AND ADDRESS OF THE APPLICANT:	Eaton Power Quality (Shanghai) Co., Ltd B5 , No76, Ribin Road, Shanghai Free Trade Zone, china,200131
BRAND NAME:	EATON
NAME AND ADDRESS OF THE MANUFACTURER:	Santak Electronic (Shenzhen) Co.,Ltd No.8 Bao shi Rd,Block 72 Bao'an District,Shenzhen,Guangdong 518101,China
NAME AND ADDRESS OF THE FACTORY:	Santak Electronic (Shenzhen) Co.,Ltd No.8 Bao shi Rd,Block 72 Bao'an District,Shenzhen,Guangdong 518101,China
PRODUCT NAME:	UPS
PRODUCT MODEL AND SPECIFICATION:	See Appendix
TYPE OF CERTIFICATION SCHEMES:	Product Testing + Initial Factory Inspection + Follow up Factory Inspection
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS:	CQC3108-2011

This is to certify that the above mentioned product(s) complies with the requirements of CQC31-461234-2009 .

Valid from: Jun.03,2019

Valid until: Jun.03,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.



President:

Lu Mei



**CHINA QUALITY CERTIFICATION CENTRE**