





中国节能产品认证证书

证书编号: CQC15701129964

申请人名称及地址: 伊顿电源(上海)有限公司
中国(上海)自由贸易试验区日滨路76号B5部位

品 牌: EATON

制造商名称及地址: 山特电子(深圳)有限公司
深圳宝安72区宝石路8号

生产企业名称及地址: 山特电子(深圳)有限公司
深圳宝安72区宝石路8号

产品名称: 不间断电源

系列/规格/型号: 见附件

认证模式: 产品检验+初始工厂检查+获证后监督

产品标准/技术要求: CQC3108-2011《不间断电源节能认证技术规范》

上述产品符合CQC31-461234-2009《不间断电源节能认证规则》认证规则的要求。

证书有效期: 2015年11月30日 至 2018年11月30日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。



主任: _____



中国质量认证中心

中国 北京 南四环西路188号9区 100070

<http://www.cqc.com.cn>

JC 0092949



CHINA CERTIFICATE For ENERGY CONSERVATION PRODUCT

Certificate No: CQC15701129964

NAME AND ADDRESS OF THE APPLICANT:	Eaton Power Quality (Shanghai) Co., Ltd B5 , No76, Ribin Road, Shanghai Free Trade Zone, china,200131
BRAND NAME:	EATON
NAME AND ADDRESS OF THE MANUFACTURER:	Santak Electronic (Shenzhen) Co.,Ltd No.8 Bao shi Rd,Block 72 Bao'an District,Shenzhen,Guangdong 518101,China
NAME AND ADDRESS OF THE FACTORY:	Santak Electronic (Shenzhen) Co.,Ltd No.8 Bao shi Rd,Block 72 Bao'an District,Shenzhen,Guangdong 518101,China
PRODUCT NAME:	UPS
PRODUCT MODEL AND SPECIFICATION:	See Appendix
CERTIFICATION MODEL:	Product Testing + Initial Factory Inspection + Follow up Factory Inspection
THE STANDARD/TECHNICAL REQUIREMENTS FOR THE PRODUCTS:	CQC3108-2011"Energy Conservation Certification Criteria for UPS"

This is to certify that the above-mentioned product meets the requirements of CQC31-461234-2009"Energy Conservation Certification Rules for UPS".

Valid dates of this Certificate: From Nov. 30, 2015 to Nov. 30, 2018

The validity of the certificate depend on the follow up inspection by the certification body at regular intervals.



President:



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

JC 0092949



中国节能产品认证证书

附录:

Appendix:

证书编号: CQC15701129964

第 1 页 共 5 页

Page 1 of 5

纸号: 92949

型号	直流输入	交流输入	逆变输出	额定功率
93E-15U-N-MBS	DC432V 34A	AC380V 3Φ+N+PE 50/60Hz 24A	AC380V 3Φ+N+PE 50/60Hz 23A	15kVA/13.5kW
93E-15U-D-MBS	DC432V 34A	AC380V 3Φ+N+PE 50/60Hz 24A	AC380V 3Φ+N+PE 50/60Hz 23A	15kVA/13.5kW
93E-15UI-N-64X9Ah-MBS	DC384V 39A	AC380V 3Φ+N+PE 50/60Hz 24A	AC380V 3Φ+N+PE 50/60Hz 23A	15kVA/13.5kW
93E-15UI-D-64X9Ah-MBS	DC384V 39A	AC380V 3Φ+N+PE 50/60Hz 24A	AC380V 3Φ+N+PE 50/60Hz 23A	15kVA/13.5kW

注: 此附录与证书同时使用时有效。

NOTE:

This appendix forms a part of the certificate for china compulsory product certification, and must be used together with the certification.



主任: _____



中国质量认证中心

中国 北京 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



中国节能产品认证证书

附录:

Appendix:

证书编号: CQC15701129964

第 2 页 共 5 页

Page 2 of 5

纸号: 92949

93E-20-N-MBS	DC432V 46A	AC380V 3Φ+N+PE 50/60Hz 32A	AC380V 3Φ+N+PE 50/60Hz 30A	20kVA/18kW
93E-20-D-MBS	DC432V 46A	AC380V 3Φ+N+PE 50/60Hz 32A	AC380V 3Φ+N+PE 50/60Hz 30A	20kVA/18kW
93E-20I-N-64x9Ah-MBS	DC384V 52A	AC380V 3Φ+N+PE 50/60Hz 32A	AC380V 3Φ+N+PE 50/60Hz 30A	20kVA/18kW
93E-20I-D-64x9Ah-MBS	DC384V 52A	AC380V 3Φ+N+PE 50/60Hz 32A	AC380V 3Φ+N+PE 50/60Hz 30A	20kVA/18kW
93E-30-N-MBS	DC432V 69A	AC380V 3Φ+N+PE 50/60Hz 48A	AC380V 3Φ+N+PE 50/60Hz 46A	30kVA/27kW

注: 此附录与证书同时使用时有效。

NOTE:

This appendix forms a part of the certificate for china compulsory product certification, and must be used together with the certification.



主任: _____



中国质量认证中心

中国 北京 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



中国节能产品认证证书

附录:

Appendix:

证书编号: CQC15701129964

第 3 页 共 5 页

Page 3 of 5

纸号: 92949

93E-30-D-MBS	DC432V 69A	AC380V 3Φ+N+PE 50/60Hz 48A	AC380V 3Φ+N+PE 50/60Hz 46A	30kVA/27kW
93E-30I-N-96x9Ah-MBS	DC384V 77A	AC380V 3Φ+N+PE 50/60Hz 48A	AC380V 3Φ+N+PE 50/60Hz 46A	30kVA/27kW
93E-30I-D-96x9Ah-MBS	DC384V 77A	AC380V 3Φ+N+PE 50/60Hz 48A	AC380V 3Φ+N+PE 50/60Hz 46A	30kVA/27kW
93E-40-N-MBS	DC432V 92A	AC380V 3Φ+N+PE 50/60Hz 65A	AC380V 3Φ+N+PE 50/60Hz 61A	40kVA/36kW
93E-40-D-MBS	DC432V 92A	AC380V 3Φ+N+PE 50/60Hz 65A	AC380V 3Φ+N+PE 50/60Hz 61A	40kVA/36kW

注: 此附录与证书同时使用时有效。

NOTE:

This appendix forms a part of the certificate for china compulsory product certification, and must be used together with the certification.



主任: _____



中国质量认证中心

中国 北京 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



中国节能产品认证证书

附录:

Appendix:

证书编号: CQC15701129964

第 4 页 共 5 页

Page 4 of 5

纸号: 92949

93E-40I-N-128x9Ah-MBS	DC384V 103A	AC380V 3Φ+N+PE 50/60Hz 65A	AC380V 3Φ+N+PE 50/60Hz 61A	40kVA/36kW
93E-40I-D-128x9Ah-MBS	DC384V 103A	AC380V 3Φ+N+PE 50/60Hz 65A	AC380V 3Φ+N+PE 50/60Hz 61A	40kVA/36kW
93E-60-N-MBS	DC432V 137A	AC380V 3Φ+N+PE 50/60Hz 97A	AC380V 3Φ+N+PE 50/60Hz 91A	60kVA/54kW
93E-60-D-MBS	DC432V 137A	AC380V 3Φ+N+PE 50/60Hz 97A	AC380V 3Φ+N+PE 50/60Hz 91A	60kVA/54kW
93E-80-N-MBS	DC432V 183A	AC380V 3Φ+N+PE 50/60Hz 129A	AC380V 3Φ+N+PE 50/60Hz 122A	80kVA/72kW

注: 此附录与证书同时使用时有效。

NOTE:

This appendix forms a part of the certificate for china compulsory product certification, and must be used together with the certification.



主任: _____



中国质量认证中心

中国 北京 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



中国节能产品认证证书

附录:

Appendix:

证书编号: CQC15701129964

第 5 页 共 5 页

Page 5 of 5

纸号: 92949

93E-80-D-MBS	DC432V 183A	AC380V 3Φ+N+PE 50/60Hz 129A	AC380V 3Φ+N+PE 50/60Hz 122A	80kVA/72kW
--------------	-------------	-----------------------------------	-----------------------------------	------------

注: 此附录与证书同时使用时有效。

NOTE:

This appendix forms a part of the certificate for china compulsory product certification, and must be used together with the certification.



主任: _____



中国质量认证中心

中国 北京 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>