



中国节能产品认证证书

证书编号: CQC18701210326

申请人名称及地址: 伊顿电源(上海)有限公司
中国(上海)自由贸易试验区日滨路76号B5部位

品 牌: EATON

制造商名称及地址: 山特电子(深圳)有限公司
深圳市宝安区72区宝石路8号

生产企业名称及地址: 山特电子(深圳)有限公司
深圳市宝安区72区宝石路8号

产 品 名 称: 不间断电源

系 列/规 格/型 号: 见附件

认 证 模 式: 产品检验+初始工厂检查+获证后监督

产品标准/技术要求: CQC3108-2011

上述产品符合 CQC31-461234-2009 认证规则的要求, 特此发证。

证 书 有 效 期: 2018年12月19日至2021年12月19日
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。



主任:

陆梅



中国质量认证中心



CHINA CERTIFICATE FOR ENERGY CONSERVATION PRODUCT

CERTIFICATE NO.: CQC18701210326

NAME AND ADDRESS OF THE APPLICANT:	Eaton Power Quality (Shanghai) Co., Ltd B5 , No76, Ribin Road, Shanghai Free Trade Zone, china,200131
BRAND NAME:	EATON
NAME AND ADDRESS OF THE MANUFACTURER:	Santak Electronic (Shenzhen) Co.,Ltd No.8 Bao shi Rd,Block 72 Bao'an District,Shenzhen,Guangdong 518101,China
NAME AND ADDRESS OF THE FACTORY:	Santak Electronic (Shenzhen) Co.,Ltd No.8 Bao shi Rd,Block 72 Bao'an District,Shenzhen,Guangdong 518101,China
PRODUCT NAME:	UPS
PRODUCT MODEL AND SPECIFICATION:	See Appendix
TYPE OF CERTIFICATION SCHEMES:	Product Testing + Initial Factory Inspection + Follow up Factory Inspection
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS:	CQC3108-2011

This is to certify that the above mentioned product(s) complies with the requirements of CQC31-461234-2009 .

Valid from: Dec.19,2018

Valid until: Dec.19,2021

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国节能产品认证证书

附 录

第 1 页 共 1 页

证书编号: CQC18701210326

纸 号: 144410

型号	交流输入	逆变输出	系统容量	外形尺寸(mm)
93PR-25(200)	AC380V, 3W+N+PE, 50/60Hz, 40A	AC380V, 3W+N+PE, 50/60Hz, 38A	25kVA/25kW	880*2210*1160
93PR-50(200)	AC380V, 3W+N+PE, 50/60Hz, 80A	AC380V, 3W+N+PE, 50/60Hz, 76A	50kVA/50kW	880*2210*1160
93PR-75(200)	AC380V, 3W+N+PE, 50/60Hz, 119A	AC380V, 3W+N+PE, 50/60Hz, 114A	75kVA/75kW	880*2210*1160

注: 此附录与证书同时使用时有效。



主任:

陆梅



中国质量认证中心



中国节能产品认证证书

证书编号：CQC18701210330

申请人名称及地址：伊顿电源（上海）有限公司
中国（上海）自由贸易试验区日滨路76号B5部位

品 牌：EATON

制造商名称及地址：山特电子（深圳）有限公司
深圳市宝安区72区宝石路8号

生产企业名称及地址：山特电子（深圳）有限公司
深圳市宝安区72区宝石路8号

产 品 名 称：不间断电源

系 列/规 格/型 号：见附件

认 证 模 式：产品检验+初始工厂检查+获证后监督

产品标准/技术要求：CQC3108-2011

上述产品符合 CQC31-461234-2009 认证规则的要求，特此发证。

证 书 有 效 期 期：2018年12月19日至2021年12月19日
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。



主任：

陆梅



中国质量认证中心



CHINA CERTIFICATE FOR ENERGY CONSERVATION PRODUCT

CERTIFICATE NO.: CQC18701210330

NAME AND ADDRESS OF THE APPLICANT:	Eaton Power Quality (Shanghai) Co., Ltd B5 , No76, Ribin Road, Shanghai Free Trade Zone, china,200131
BRAND NAME:	EATON
NAME AND ADDRESS OF THE MANUFACTURER:	Santak Electronic (Shenzhen) Co.,Ltd No.8 Bao shi Rd,Block 72 Bao'an District,Shenzhen,Guangdong 518101,China
NAME AND ADDRESS OF THE FACTORY:	Santak Electronic (Shenzhen) Co.,Ltd No.8 Bao shi Rd,Block 72 Bao'an District,Shenzhen,Guangdong 518101,China
PRODUCT NAME:	UPS
PRODUCT MODEL AND SPECIFICATION:	See Appendix
TYPE OF CERTIFICATION SCHEMES:	Product Testing + Initial Factory Inspection + Follow up Factory Inspection
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS:	CQC3108-2011

This is to certify that the above mentioned product(s) complies with the requirements of CQC31-461234-2009 .

Valid from: Dec.19,2018

Valid until: Dec.19,2021

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国节能产品认证证书

附 录

第 1 页 共 1 页

证书编号: CQC18701210330

纸 号: 144411

型号	交流输入	逆变输出	系统容量	外形尺寸 (mm)
93PR-100 (200)	AC380V, 3W+N+PE, 50/60Hz, 159A	AC380V, 3W+N+PE, 50/60Hz, 152A	100kVA/100kW	880*2210*1160
93PR-125 (200)	AC380V, 3W+N+PE, 50/60Hz, 198A	AC380V, 3W+N+PE, 50/60Hz, 189A	125kVA/125kW	880*2210*1160
93PR-150 (200)	AC380V, 3W+N+PE, 50/60Hz, 238A	AC380V, 3W+N+PE, 50/60Hz, 227A	150kVA/150kW	880*2210*1160
93PR-175 (200)	AC380V, 3W+N+PE, 50/60Hz, 278A	AC380V, 3W+N+PE, 50/60Hz, 265A	175kVA/175kW	880*2210*1160
93PR-200 (200)	AC380V, 3W+N+PE, 50/60Hz, 317A	AC380V, 3W+N+PE, 50/60Hz, 306A	200kVA/200kW	880*2210*1160

注: 此附录与证书同时使用时有效。



主任:

陆梅



中国质量认证中心