

Declaration of Conformity

We, **Eaton Power Quality Oy**
Koskelontie 13, P.O. Box 54, 02921 Espoo
Finland

Date of affixing 2016

declare under our sole responsibility that product

Eaton 9PHD 20-200kW Industrial UPS

Manufactured, configured to order and tested at:

Eaton Power Quality Oy
Koskelontie 13, P.O.Box 54,
02921 Espoo, Finland

provided that it is installed, maintained and used in the application intended for, with respect to the relevant manufacturer's instructions, installation standards and "good engineering practices"

complies with the provisions of Council directive(s):

2014/35/EU	<i>Low Voltage Directive</i>
2014/30/EU	<i>EMC Directive</i>

based on compliance with European standard(s):

EN 62040-1: 2008 + EN 62040-1:2008/A1:2013
Uninterruptible Power Systems (UPS) – Part 1: General and safety requirements for UPS.

EN 62040-2: 2006
Uninterruptible power systems (UPS) – Part 2: Electromagnetic compatibility (EMC) requirements.
(UPS of Category C3)

2018-04-12, Espoo Finland



Otto Asunmaa
Head of R&D
Eaton Power Quality Oy



Powering Business Worldwide

Types within the range

The declaration of conformity applies to the following types within the product family:

Product description	9PHD-AAA(BBB)-CC-DDD-EEE-F-GG-HH-JJJJJJJJKKKK
----------------------------	---

Where:

Power

AAA: 20, 30, 40, 50, 60, 80, 90, 100, 120, 150, 160, 200

Scalability

BBB: 30, 40, 50, 60, 80, 90, 100, 120, 150, 160, 200

Input switch

CC: (blank), IS

Maintenance switch

DDD: (blank), MBS

Redundancy

EEE: (blank), N+1

Front-to-up airflow

F: (blank), A

Internal configuration

GG: (blank), 3W, IT

Seismic

HH: (blank), SE

Input transformer, battery, ATS

switch option
JJJJJJJ: (blank), ATS, 4x36x9Ah, xxx, Txxx, TAxxx, TxxxTxxx, TxxxTAxxx, TAxxxTxxx, TAxxxTAxxx

Output transformer option

KKKKK: (blank), /-, /xxx, /Txxx, /TAxxx

Transformer voltage

xxx: 208-690



Powering Business Worldwide