



PROVISIONS FOR BOLTING RPP TO FLOOR STAND

FOOT PRINT

FRONT & SIDE VIEW  
(DOOR & COVERS REMOVED)

**NOTES:**

1. HINGED REMOVABLE PANELS PROVIDED ON SIDES.
2. ACCESS: MINIMUM 36" FROM FRONT & REAR OF ENCLOSURE, IS REQUIRED FOR OPERATION. ACCESS ON ONE SIDE IS REQUIRED FOR INSTALLATION & MAINTENANCE.
3. APPROXIMATE WEIGHT: 600lbs.
4. (2) INPUT CIRCUIT BREAKERS, (2) 42 CIRCUIT PANEL BOARDS
5. (120)- 0.875Ø KNOCKOUTS PROVIDED.
6. SYNC CHECK RELAY SUPPLIED WITH SKRU.
7. NEUTRAL SWITCHING CONTACTORS - SQ D. P/N LCIF185.

THIS DRAWING CONTAINS CONFIDENTIAL & PROPRIETARY INFORMATION AND SHALL NOT BE DISCLOSED OR COPIED WITHOUT THE EXPRESSED, WRITTEN PERMISSION OF POWER DISTRIBUTION INC.		TITLE		-OUTLINE-	
		REMOTE POWER PANEL(RPP) W/(2)INPUT CIRCUIT BREAKERS (2)42 CIRCUIT PANELBOARDS AND PDI WAVESTAR MONITOR			
		DWG. NUMBER	SHEET 1 OF 1	REVISION	
		RPP18154		-A-	
DRAWN BY	ISF	CHECKED BY	LN		
DATE	04-02-15	DATE	04-02-15		

