



# Certificate of Compliance

**Certificate:** 2021470

**Master Contract:** 163545

**Project:** 80049898

**Date Issued:** 2020-07-31

**Issued To:** Eaton Corporation  
1000 Cherrington Pkwy  
Moon Township, Pennsylvania, 15108  
United States

**Attention:** John Clark

*The products listed below are eligible to bear the CSA Mark shown*

**Issued by:** Zhibin Li  
Zhibin Li



## **PRODUCTS**

**CLASS - C143201 - CIRCUIT BREAKERS Moulded Case Type**

Moulded Case Circuit Breaker, Types CSR, CSH, BW, BWH, BWHH, CM, CMH, CMV, rated 100-225A, 120/240V ac 2-pole.

### **Interrupting Ratings:**

Type	Name	Description
CSR	Cutler-Hammer	2 Pole, 120/240V, 50/60Hz, 25,000 AIC
BW	Westinghouse	2 Pole, 120/240V, 50/60Hz, 10,000 AIC
BWH	Westinghouse	2 Pole, 120/240V, 50/60Hz, 25,000 AIC
CM	Challenger	2 Pole, 120/240V, 50/60Hz, 10,000 AIC
CMH	Challenger	2 Pole, 120/240V, 50/60Hz, 25,000 AIC
CSH	Cutler-Hammer	2 Pole, 120/240V, 50/60Hz, 35,000 AIC
BWHH	Westinghouse	2 Pole, 120/240V, 50/60Hz, 35,000 AIC
CMV	Challenger	2 Pole, 120/240V, 50/60Hz, 35,000 AIC



**Certificate:** 2021470  
**Project:** 80049898

**Master Contract:** 163545  
**Date Issued:** 2020-07-31

---

**APPLICABLE REQUIREMENTS**

CSA Std C22.2 No.5 - Moulded Case Circuit Breakers



## *Supplement to Certificate of Compliance*

**Certificate:** 2021470

**Master Contract:** 163545

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
80049898	2020-07-31	Update report 2021470 to cover alternate wire connectors; also covers alternate material for breaker base and cover; also covers evaluation to CSA Notice Breaker No.4A and 6, Informs Breaker No.3.
0002021470	2008-08-25	Extension of Current Ratings