



# Certificate of Compliance

**Certificate:** 70044835

**Master Contract:** 163545

**Project:** 70044835

**Date Issued:** September 26, 2015

**Issued to:** Eaton Corporation  
1000 Cherrington Pkwy  
Moon Township, PA 15108  
USA  
Attention: Kevin J. Lippert

*The products listed below are eligible to bear the CSA Mark shown*



*Steve Jeffery*

**Issued by:** Steve Jeffery

## **PRODUCTS**

**CLASS 1451 01** - GROUND FAULT DEVICES - Circuit Interrupters

Combined circuit breaker and ground fault circuit interrupters, unclassified, 30 mA sensitivity, Cat Nos GFEB, GFEP, QPGFEP and QBGFEP, 15-30 A, 120 V ac, 1-pole, 15-40 A, 120/240 V ac, 2-pole.

Combined circuit breaker and ground fault circuit interrupters, unclassified, 30-100 mA sensitivity, Cat Nos GFEB, and GFEP, 15-30 A, 120 V ac, 1-pole.

## Notes:

1. These devices are Certified for use only in enclosures where the suitability of the combination has been determined by the Canadian Standards Association.
2. These devices may be marked with the following interrupting rating.

Catalogue Number	No of Poles	HIC Rating
GFEB, GFEP	1	22 kA at 120 V ac



**Certificate:** 70044835

**Master Contract:** 163545

**Project:** 70044835

**Date Issued:** September 26, 2015

---

QPGFEP, QBGFEP		(Cat No with Suffix H) 10 kA at 120 V ac
QPGFEP, QBGFEP	2	(Cat No without Suffix H) 22 kA at 120/240 V ac
		(Cat No with Suffix H) 10 kA at 120/240 V ac
		(Cat No without Suffix H)

**APPLICABLE REQUIREMENTS**

CSA C22.2 No 5-13 - Moulded - Case Circuit Breakers, Moulded - Case Switches and Circuit Breaker Enclosures

CSA C2.2 No 144-M91 - Ground Fault Circuit Interrupters