



Certificate of Compliance

Certificate: 80030457 (LR 87196-2)

Master Contract: 163545

Project: 80030457

Date Issued: 2020-01-09

Issued To: Eaton Corporation
1000 Cherrington Pkwy
Moon Township, Pennsylvania, 15108
United States

Attention: John Clark

Issued by: *Zhibin Li*
Zhibin Li



PRODUCTS

CLASS - C143201 - CIRCUIT BREAKERS Moulded Case Type

PART A -Circuit breakers, Types CH3 and CHB3, 80-125A, 120/240V ac, 2-pole and 80-100A, 240V ac, 3-pole; Types CH and CHB, 15-70A, 240V ac, 3-pole, and 60-70A, 120/240V ac, 1-pole. Type CHB4, Rated 60 to 125A, 2 Pole common trip, 120/240 V ac. Circuit breaker may be designated TMQB when manufactured for General Electric.

Switched neutral circuit breakers, Type CH and CHB, 15, 20, 30, 40, 50A, 120V ac, 2 pole and 120/240V ac, 3 pole.

Notes:

1. These devices are suitable for reverse line and load connections.
2. These devices are suitable for use at 40C without provision for ambient compensation.
3. CH3 and CH3B are rated 10KA, 240Vac maximum.
4. CHB4 is rated at 42kA, 240Vac maximum.



Certificate: 80030457 (LR 87196-2)
Project: 80030457

Master Contract: 163545
Date Issued: 2020-01-09

CLASS 1437 01 - CIRCUIT BREAKERS - Accessories

PART B -Shunt trip accessory for factory installation in the submitter's Types CH, CH3, CHB and CHB3 circuit breakers.

APPLICABLE REQUIREMENTS

CAN/CSA C22.2 5 - Moulded Case Circuit Breakers



Supplement to Certificate of Compliance

Certificate: 80030457

Master Contract: 163545

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80030457	2020-01-09	Supersede report LR 87196-2 and cover alternate connector, 80-5748-2, 80-5862-2; Also covers addition of Breaker, CHB4.