


## Deklaracja zgodności składana przez dostawcę (zgodnie z ISO/IEC 17050-1)

Nazwa wystawo	ry: Eaton Electric Sp. z o.o	Eaton Electric Sp. z o.o	
Adres wystawcy	ul. Galaktyczna 30, 80-299 Gdańsk, NIP: 584	ul. Galaktyczna 30, 80-299 Gdańsk, NIP: 5841022327	
Przedmiot dekla	aracji: Podstawy bezpiecznikowe dla przemysłowycl	n bezpieczników	
Przedmiot dekla	aracji opisany powyżej jest zgodny z wymaganiami	następujących dokumentów:	
Nr dokumentu	Tytuł	Data wydania	
CE2100077	EC Declaration of Conformity zgodny z normami:	25.03.2021	
	EN 60269-1:2007 + A1:2009 + A2:2014		
	EN IEC 63000:2018		
	i zgodny z postanowieniami odpowiednich dyrektyw:		
	Dyrektywa Niskonapięciowa 2014/35/EU		
	Dyrektywa RoHS 2011/65/EU		







## Informacje dodatkowe

Na podstawie deklaracji zgodności CE wystawionej przez producenta Eaton Corporation – w załączeniu.

Podpisano:

kemata Janusuwska

Eaton Electric Sp. z o.o.

80-299 Gdańsk ul. Galaktyczna 30 NIP: 584-10-22-327

Renata Januszewska
Brand Development Manager Fire & Safety

Gdańsk, 05.09.2022 (Miejsce i data wystawienia)

Powyższa deklaracja zgodności dotyczy następujących typów produktów w ramach rodziny produktów:


SM32B

SM63B

SM32H

SM63H





Doc. No.: CE2100077

## **EU** declaration of conformity

We, Eaton Electrical Products Ltd. Melton Road, Burton-on-the-Wolds, Leicestershire, LE12 5TH, UK

declare under our sole responsibility as manufacturer that the product (family)

## **Fuse-holders for industrial fuse-links**

according to the list on page 2 and provided that it is installed, maintained and used in the application intended for, with respect to the relevant manufacturer's instructions, installation standards and "good engineering practices",

complies with the provisions of Council directive(s):

2014/35/EU Low Voltage Directive

2011/65/EU RoHS Directive

based on compliance with the following standard(s):

EN 60269-1:2007 + A1:2009 + A2:2014


EN IEC 63000:2018

Leicestershire, 25.03.2021

i.A. Edgar Willems
Director Quality
Industrial Controls & Protection Division

i.A. Bill Butters Head of Product Line Management Power Switching & Protection







Leicestershire, 25.03.2021

i.A. Edgar Willems
Director Quality
Industrial Controls & Protection Division

i.A. Bill Butters

Head of Product Line Management

Power Switching & Protection