



Certificate of Compliance

Certificate: 2678084

Master Contract: 163545

Project: 2678084

Date Issued: December 2, 2013

Issued to: Eaton Corporation
1000 Cherrington Pkwy
Moon Township, PA 15108
USA
Attention: Lou Grahor

*The products listed below are eligible to bear the
CSA Mark shown with adjacent indicator 'US'*



Steve Jeffery

Issued by: Steve Jeffery

PRODUCTS

CLASS 1432 81 - CIRCUIT BREAKERS - Moulded Case Type - Certified to U.S. Standards

Type FD-PV, 30-100A, 1000V dc, 4-pole, 1000V dc – 3kA interrupting rating circuit breakers for use in Photovoltaic (PV) Systems

Notes:

Note: Prefix letter C may be added to type designation to denote 100% rated circuit breaker.

APPLICABLE REQUIREMENTS

UL 489B – Moulded Case Circuit Breakers For Use With Photovoltaic (PV) Systems