



Certificate of Compliance

Certificate: 2701430

Master Contract: 163545

Project: 2701430

Date Issued: February 19, 2014

Issued to: Eaton Corporation

1000 Cherrington Pkwy
Moon Township, PA 15108
USA
Attention: Lou Grahor

*The products listed below are eligible to bear the
CSA Mark shown with adjacent indicator 'US'*



Steve Jeffery

Issued by: Steve Jeffery

PRODUCTS

CLASS 1432 81 - CIRCUIT BREAKERS - Moulded Case Type - Certified to U.S. Standards

Type JG-PVS, 90 - 250A, 600V dc, 3-pole, 600V dc – 1.2kA interrupting rating circuit breakers for use in Photovoltaic (PV) Systems.

Notes:

Note: Prefix letter C may be added to type designation to denote 100% rated circuit breaker.

APPLICABLE REQUIREMENTS

UL 489B – Moulded Case Circuit Breakers For Use With Photovoltaic (PV) Systems