



Certificate of Compliance

Certificate: 2678087

Master Contract: 163545

Project: 2678087

Date Issued: December 2, 2013

Issued to: Eaton Corporation
1000 Cherrington Pkwy
Moon Township, PA 15108
USA
Attention: Lou Grahor

*The products listed below are eligible to bear the
CSA Mark shown with adjacent indicator 'US'*



Steve Jeffery

Issued by: Steve Jeffery

PRODUCTS

CLASS 1432 81 - CIRCUIT BREAKERS - Moulded Case Type - Certified to U.S. Standards

Type MDL-PV, 300 - 600A, 1000V dc, 4-pole, 1000V dc – 7.5kA interrupting rating circuit breakers for use in Photovoltaic (PV) Systems.

APPLICABLE REQUIREMENTS

UL 489B – Moulded Case Circuit Breakers For Use With Photovoltaic (PV) Systems