



Certificate of Compliance

Certificate: 1444573 **Master Contract:** 163545 (042193_0_000)

Project: 70191595 **Date Issued:** 2018-07-19

Issued to: Eaton Corporation
1000 Cherrington Pkwy
Moon Township, Pennsylvania 15108
USA
Attention: Kevin J. Lippert

The products listed below are eligible to bear the CSA Mark shown



Issued by: Zhibin Li
Zhibin Li

PRODUCTS

CLASS - C143201 - CIRCUIT BREAKERS-Moulded Case Type

Moulded Case Circuit Breaker, Type "EF" frame, Types EGB, EGE, EGS, EGH, 15-125A, 1-pole, 347Vac, 125Vdc, 2-4pole, 347/600V ac, 480V ac, 125/250V dc.

Moulded Case Circuit Breaker with Current Limiter Module, Type EFC, EGC, EFQ and EGQ, 15-100A, 3 pole, 347/600V ac, 480V ac, 240V ac, 125/250V dc.

Moulded Case Circuit Breaker, Types EF-E-DC, EF-S-DC, EF-H-DC, 25-100A, 125V dc, 1pole, 250V dc, 2 poles in series, 500V dc, 3 poles in series.

Moulded Case Circuit Breaker, Types PDG1, 15-125A, 1-pole, 347Vac, 125Vdc, 2-4pole, 347/600V ac, 480V ac, 125/250V dc.

Notes:

1. These circuit breakers may be marked with the following interrupting ratings:

Type	Poles	600Y/347 V ac	480V ac	347V ac	277V ac	240V ac	125V dc	125/250V dc	250V dc	500V dc
EF-B	1	-	-	-	18	25	10	-		



Certificate: 1444573
Project: 70191595

Master Contract: 163545
Date Issued: 2018-07-19

EF-B	2, 3, 4	-	18	-	-	25	-	10		
EF-E	1	-	-	-	-	-	-	-		
EF-E	2, 3, 4	18	25	-	-	65	-	10		
EF-S	1	-	-	22	35	85	35	-		
EF-S	2, 3, 4	22	35	-	-	85	-	35		
EF-H	1	-	-	30	65	100	42	-		
EF-H	2, 3, 4	25	65	-	-	100	-	42		
EF-C	3,4	35	100	-	-	200	-	42		
EF-Q	3	100	150	-	-	200	-	42		
EF-E-DC	3	-	-	-	-	-	10	-	35	35
EF-S-DC	3	-	-	-	-	-	35	-	42	50
EF-H-DC	3	-	-	-	-	-	42	-	50	65

250V dc is wired 2 poles in series, 500V dc is wired 3 poles in series.

2. Type EGB, EGE, EGS, EGH circuit breakers are suitable for reverse line and load connectors.
3. Type EFC, EGC, EFQ and EGQ circuit breakers are not suitable for reverse line and load connections.
4. The interrupting rating of PDG1 are the same as Type EGB, EGE, EGS, EGH circuit breakers.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 5 - Moulded Case Circuit Breakers



Supplement to Certificate of Compliance

Certificate: 1444573

Master Contract: 163545 (042193_0_000)

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70191595	2018-07-19	Update report 1444573 to cover additional Cat. No. PDG1
2596650	2013-04-11	Addition of a double thick top plate on the arc chute and a barrier on the moving contact arm
2451277	2011-12-12	Moulded Case Circuit Breaker
2316188	2010-10-05	Moulded Case Circuit Breaker
1444573	2003-10-15	Moulded Case Circuit Breaker, Type EF frame.