

中国国家强制性产品认证证书

证书编号：2018010307095060

委托人名称、地址

伊顿电气有限公司
苏州工业园区娄阳路2号

生产者（制造商）名称、地址

伊顿电气集团
1000 Cherrington Parkway Moon Township, PA 15108, USA

生产企业名称、地址

Cutler Hammer Industries, LTD
Parque Industrial Itabo KM 18 Carretera SanchezHaina, DR 33166-6503

产品名称和系列、规格、型号

塑料外壳式断路器

PDG1: Uimp:6kV; Ui:500V; Ue:AC240V,AC415V,DC250V ;

In:15A,16A,20A,25A,30A,32A,35A,40A,45A,50A,60A,63A,70A,80A,90A,100A,110A,125A; 过电流脱扣器类型:

热磁式; C:lcs=Icu=25kA(AC240V),lcs=Icu=18kA(AC415V),lcs=Icu=10kA(DC250V);

F:lcs=Icu=35kA(AC240V),lcs=Icu=25kA(AC415V),lcs=Icu=10kA(DC250V);

G:lcs=43kA,Icu=85kA(AC240V),lcs=30kA,Icu=40kA(AC415V),lcs=Icu=35kA(DC250V);

K:lcs=50kA,Icu=100kA(AC240V),lcs=35kA,Icu=70kA(AC415V),lcs=Icu=42kA(DC250V); 使用类别:A; 极

数:3P,4P; 不适用于隔离; 型号解释见附件

产品标准和技术要求


GB/T14048. 2-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，
特发此证。

发证日期：2018年07月19日 有效期至：2020年06月17日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。


本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任：



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2018010307095060

NAME AND ADDRESS OF THE APPLICANT

Eaton Electrical Ltd.
No.2, Louyang Road, Suzhou Industrial Park

NAME AND ADDRESS OF THE MANUFACTURER

Eaton Electrical Inc.
1000 Cherrington Parkway Moon Township, PA 15108, USA

NAME AND ADDRESS OF THE FACTORY

Cutler Hammer Industries, LTD
Parque Industrial Itabo KM 18 Carretera SanchezHaina, DR 33166-6503

PRODUCT NAME, MODEL AND SPECIFICATION

Moulded case circuit breaker

PDG1: Uimp:6kV; Ui:500V; Ue:AC240V,AC415V,DC250V ; In:15A,16A,20A,25A,30A,32A,35A,40A,45A,50A,60A,63A,70A,80A,90A,100A,110A,125A; hermal Magnetic Over-current Release; C:Ics=Icu=25kA(AC240V),Ics=Icu=18kA(AC415V),Ics=Icu=10kA(DC250V); F:Ics=Icu=35kA(AC240V),Ics=Icu=25kA(AC415V),Ics=Icu=10kA(DC250V); G:Ics=43kA,Icu=85kA(AC240V),Ics=30kA,Icu=40kA(AC415V),Ics=Icu=35kA(DC250V); K:Ics=50kA,Icu=100kA(AC240V),Ics=35kA,Icu=70kA(AC415V),Ics=Icu=42kA(DC250V); Utilization Category: A; Poles:3P,4P; Un suitable for isolation;

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008


This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Jul.19,2018

Valid until: Jun.17,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through CNCA's website: www.cnca.gov.cn




President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

证书编号：2018010307095062

委托人名称、地址

伊顿电气有限公司
苏州工业园区娄阳路2号

生产者（制造商）名称、地址

伊顿电气集团
1000 Cherrington Parkway Moon Township, PA 15108, USA

生产企业名称、地址

Cutler Hammer Industries, LTD
Parque Industrial Itabo KM 18 Carretera SanchezHaina, DR 33166-6503

产品名称和系列、规格、型号

塑料外壳式断路器


PDG1: Uimp:6kV;Ui:500V;Ue:AC240V,AC415V,DC250V(二极
串);In:15A,16A,20A,25A,30A,32A,35A,40A,45A,50A,60A,63A,70A,80A,90A,100A,110A,125A;过电流脱扣器
类型:热磁式;lcs=lcu=200kA(AC240V),lcs=lcu=100kA(AC415V),lcs=lcu=42kA(DC250V);使用类别:A;极
数:3P,4P;适用于隔离;型号解释见附件

产品标准和技术要求

GB/T14048. 2-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，
特发此证。


发证日期：2018年07月19日 有效期至：2019年12月16日
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。
本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任：



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2018010307095062

NAME AND ADDRESS OF THE APPLICANT

Eaton Electrical Ltd.

No.2, Louyang Road, Suzhou Industrial Park

NAME AND ADDRESS OF THE MANUFACTURER

Eaton Electrical Inc.

1000 Cherrington Parkway Moon Township, PA 15108, USA

NAME AND ADDRESS OF THE FACTORY

Cutler Hammer Industries, LTD

Parque Industrial Itabo KM 18 Carretera SanchezHaina, DR 33166-6503

PRODUCT NAME, MODEL AND SPECIFICATION

Moulded case circuit breaker

PDG1: Uimp:6kV;Ui:500V;Ue:AC240V,AC415V,DC250V(2 poles in serial); In:15A,16A,20A,25A,30A,32A,35A, 40A,45A,50A,60A,63A,70A,80A,90A,100A,110A,125A ;Over current release type:Thermal-magnetic type; Ics=Icu=200kA(AC240V),Ics=Icu=100kA(AC415V),Ics=Icu=42kA(DC250V);Utilization Category:A; Poles:3P,4P;Suitable for isolation;

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008


This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Jul.19,2018

Valid until: Dec.16,2019

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through CNCA's website: www.cnca.gov.cn




President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附录

第 1 页 共 1 页

证书编号: 2018010307095060


纸号: 2003994

型号解释:

□□□□	□	□	□□□□	□□□	□	□
I	II	III	IV	V	VI	VII

Digit	Values	Description
I Circuit breaker type	PDG1	Circuit breaker
II Pole Types	3	Three pole
	4	Four pole (100% Neutral protection)
III Breaking Capacity	See table	See table
IV Rated Current A	0015	15A
	0016	16A
	0020	20A
	0025	25A
	0030	30A
	0032	32A
	0035	35A
	0040	40A
	0045	45A
	0050	50A
	0060	60A
	0063	63A
	0070	70A
	0080	80A
0090	90A	
0100	100A	
0110	110A	
0125	125A	
V Trip Unit Type	T	Thermal Magnetic trip unit
VI Thermal Adjustment	F	Fixed Thermal
VII Mag Adjustment	F	Fixed Mag


注: 此附录与证书同时使用时有效。



主任:



中国质量认证中心



中国国家强制性产品认证证书

附 录

第 1 页 共 1 页

证书编号: 2018010307095062


纸 号: 2003995

型号解释:

□□□□	□	□	□□□□	□□□	□	□
I	II	III	IV	V	VI	VII

Digit	Values	Description
I Circuit breaker type	PDG1	Circuit breaker
II Pole Types	3	Three pole
	4	Four pole (100% Neutral protection)
III Breaking Capacity	See table	See table
IV Rated Current A	0015	15A
	0016	16A
	0020	20A
	0025	25A
	0030	30A
	0032	32A
	0035	35A
	0040	40A
	0045	45A
	0050	50A
	0060	60A
	0063	63A
	0070	70A
	0080	80A
	0090	90A
0100	100A	
0110	110A	
0125	125A	
V Trip Unit Type	T	Thermal Magnetic trip unit
VI Thermal Adjustment	A	Thermal Adjustable
VII Mag Adjustment	F	Fixed Mag

注: 此附录与证书同时使用时有效。



主 任:



中国质量认证中心