



Certificate of Compliance

Certificate: 1369437 **Master Contract:** 163545 (043556_0_000)

Project: 70204161 **Date Issued:** 2018-11-07

Issued to: Eaton Corporation
 1000 Cherrington Pkwy
 Moon Township, Pennsylvania 15108
 USA
 Attention: Kevin J. Lippert

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Zhibin Li*
 Zhibin Li

PRODUCTS

CLASS - C143201 - CIRCUIT BREAKERS-Moulded Case Type

Part A: Moulded case circuit breaker, Type MDL frame, Type MDL, MDLB, CMDLB, HMDL, HMDLB, CHMDLB, HMDLDC, 800A, 600V ac and 250V dc in 2 and 3-pole configurations.

Notes: These circuit breakers may be marked with the following high current interrupting ratings.

Breaker Type	Frequency, Hz	Interrupting Capacity (kA)			
		240V ac	480V ac	600V ac	250V dc
MDL, MDLB, CMDLB	50/60	65	50	25	22
HMDL, HMDLB, CHMDLB	50/60	100	65	35	25

Breaker Type	125V dc	Interrupting Capacity (kA)	
		250V dc +	*600V dc +
HMDLDC	42 (1 pole)	50 (2 pole) +	35 (3 pole) +

+ Poles in series.

Part B: Moulded case circuit breaker, Type PDG4 series and PDF4 series, 800A, 600V ac and 250V dc, 2, 3-pole AND 4 poles configurations. The type designation as listed in report section; The Magnetic trip unit, type PD4 series and Solid state trip unit, PD4 series.



Certificate: 1369437
Project: 70204161

Master Contract: 163545
Date Issued: 2018-11-07

Notes:

1. These circuit breakers may be marked with the following high current interrupting ratings.

Breaker Type	Interrupting Capacity (kA)			
	240V ac	480V ac	600V ac	250V dc
PDG4xG, PDF4xG	65	35	18	22
PDG4xK, PDF4xK	85	50	25	22
PDG4xM, PDF4xM	100	65	35	25

PDG4 and PDF4 series breaker are suitable for both normal and reverse feed application.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 5 - Moulded Case Circuit Breakers



Supplement to Certificate of Compliance

Certificate: 1369437

Master Contract: 163545 (43556_0_000)

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70204161	2018-11-07	Update report 1369437 to cover additional Moulded case circuit breaker, Type PDG4 series and PDF4 series, 800A, 600V ac and 250V dc, 2, 3-pole AND 4 poles configurations. The type designation as listed in report section; The Magnetic trip unit, type PD4 series and Solid state trip unit, PD4 series.
2452441	2011-12-12	Change in company names for moulding materials for MDL frame. Alternate construction of load conductor and load copper nut
2142488	2009-06-24	Increased 250VDC Interrupting Rating for HMDLDC breaker