



中国国家强制性产品认证证书

证书编号: 2011010307507260

委托人名称、地址

伊顿电气集团
1000 Cherrington Parkway Moon Township, PA 15108

生产者(制造商)名称、地址

伊顿电气集团
1000 Cherrington Parkway Moon Township, PA 15108

生产企业名称、地址

Cutler Hammer Industries, LTD
Parque Industrial Itabo KM 18 Carretera Sanchez Haina, DR

产品名称和系列、规格、型号

塑料外壳式断路器

GWF;额定工作电压(Ue): 1P: AC240V; 2P, 3P: AC240V, AC415V, AC440V, DC250V
(二极串);额定电流(In): 1P, 2P: 16A, 20A, 25A, 32A, 40A, 50A, 63A, 80A,
100A;3P: 16A, 20A, 25A, 32A, 40A, 50A, 63A, 80A, 100A, 125A;过电流脱扣器类
型: 热磁式;额定运行短路分断能力(Ics): 1P: 9kA/AC240V; 2P, 3P: 33kA/AC240V,
13kA/AC415V, 7kA/AC440V, 5kA/DC250V;额定极限短路分断能力(Icu): 1P:
18kA/AC240V; 2P, 3P: 65kA/AC240V, 25kA/AC415V, 14kA/AC440V, 10kA/DC250V;使
用类别: A;极数: 1P, 2P, 3P

产品标准和技术要求

GB 14048.2-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2016年09月12日 有效期至: 2021年09月12日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2011年11月08日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1537887



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2011010307507260

NAME AND ADDRESS OF THE APPLICANT

Eaton Electrical Inc.
1000 Cherrington Parkway Moon Township, PA 15108

NAME AND ADDRESS OF THE MANUFACTURER

Eaton Electrical Inc.
1000 Cherrington Parkway Moon Township, PA 15108

NAME AND ADDRESS OF THE FACTORY

Cutler Hammer Industries, LTD
Parque Industrial Itabo KM 18 Carretera Sanchez Haina, DR

NAME, MODEL AND SPECIFICATION

Moulded case circuit breaker

GWF;Ue: 1P: AC240V; 2P, 3P: AC240V, AC415V, AC440V, DC250V(2Poles);In: 1P, 2P: 16A, 20A, 25A, 32A, 40A, 50A, 63A, 80A, 100A;3P: 16A, 20A, 25A, 32A, 40A, 50A, 63A, 80A, 100A, 125A;Overcurrent Trip Unit: Thermal-magnetic;Ics: 1P: 9kA/AC240V; 2P, 3P: 33kA/AC240V, 13kA/AC415V, 7kA/AC440V, 5kA/DC250V;Icu: 1P: 18kA/AC240V; 2P, 3P: 65kA/AC240V, 25kA/AC415V, 14kA/AC440V, 10kA/DC250V;Utilization Category: A;Poles: 1P, 2P, 3P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.2-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-C03-02:2014).

Date of issue: Sep.12,2016 Date of expiry: Sep.12,2021

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Nov.08,2011

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

Q 1537887