



中国国家强制性产品认证证书

证书编号：2013010307600216

委托人名称、地址

伊顿电气集团

1000 Cherrington Parkway Moon Township, PA 15108, USA

生产者（制造商）名称、地址

伊顿电气集团

1000 Cherrington Parkway Moon Township, PA 15108, USA

生产企业名称、地址

伊顿电气 比佛工厂

One Tuscarwas Road, Beaver , PA15009, USA

产品名称和系列、规格、型号

塑料外壳式断路器

HMDLDC,HMDL(型号解释详见附件);Ui:1000V;Ue:DC1000V(三相串),AC415V;
In:300A,350A,400A,450A,500A,600A,700A,800A;过电流脱扣器类型:热磁式;
HMDLDC:lcs=lcu=10kA;HMDL:lcs=50kA,lcu=70kA;使用类别:A,3P;直流接线方式见附件

产品标准和技术要求

GB/T14048.2-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，
特发此证。

发证日期：2018 年 07 月 04 日 有效期至：2022 年 09 月 11 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2013 年 03 月 04 日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任：



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2013010307600216

NAME AND ADDRESS OF THE APPLICANT

Eaton Electrical Inc.
1000 Cherrington Parkway Moon Township, PA 15108, USA

NAME AND ADDRESS OF THE MANUFACTURER

Eaton Electrical Inc.
1000 Cherrington Parkway Moon Township, PA 15108, USA

NAME AND ADDRESS OF THE FACTORY

Eaton Electrical Inc. Beaver
One Tuscarwas Road, Beaver, PA15009, USA

PRODUCT NAME, MODEL AND SPECIFICATION

Molded Case Circuit Breaker

HMDLDC,HMDL;Ui:1000V;Ue:DC1000V(3 Poles in Series),AC415V; In:300A,350A,400A,450A,500A,600A,700A,800A; Over-current Trip Unit:Thermal-magnetic; HMDLDC:Ics=Icu=10kA;HMDL:Ics=50kA,Icu=70kA; Utilization Category:A;3P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Jul.04,2018

Valid until: Sep.11,2022

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Mar.04,2013

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书


附 录

第 1 页 共 2 页


证书编号：2013010307600216

纸 号：1990241

直流产品接线方式：



三极串



三极串

注：此附录与证书同时使用时有效。



主 任：



中国质量认证中心



中国国家强制性产品认证证书

附 录

第 2 页 共 2 页

证书编号：2013010307600216

纸 号：1990241

型号解释：

HMDLDC	W	3	800	W
(1)	(2)	(3)	(4)	(5)

(1) 型号

Series C

HMDLDC---- 直流-M(800 max)

HMDL---- 交流-M(800 max)

(2) W

W----表示销售往中国

(3) 极数

3-3 Pole

(4) 额定电流

300=300A

350=350A

400=400A

450=450A

500=500A

600=600A

700=700A

800=800A

(5) 尾标

L = Line and load terminals

W = Without terminals

注：此附录与证书同时使用时有效。



主 任：



中国质量认证中心