



Certificate of Compliance

Certificate: 2309926

Master Contract: 163545

Project: 2309926

Date Issued: May 27, 2010

Issued to: Eaton Corporation
1000 Cherrington Pkwy
Moon Township, PA 15108
USA
Attention: Lou Grahor

The products listed below are eligible to bear the CSA Mark shown



Steve Jeffery

Issued by: Steve Jeffery

PRODUCTS

CLASS 1432 01 - CIRCUIT BREAKERS - Moulded Case Type

PART A -Moulded case circuit breaker, Types GB and GC, 15-100A, 120V ac, 1-pole, 240V ac, 2- and 3-pole.

Moulded case circuit breaker, Types GHB and GHC, 15-100A, 277V ac, 1-pole, 277/480V ac, 2- and 3-pole.

Moulded case circuit breaker, Type GD, 15-100A, 480V ac, 3-pole. IR22kA at 480Vac, IR65kA at 240Vac.

Moulded case circuit breaker, Type GD, 15.50A, 480 Vac, 2-pole, IR14kA at 480Vac.

PART B -Circuit breaker accessory kits, factory installed or for field installation for use with submittor's CSA Certified Type GB, GC, GHB, GHC circuit breakers as follows:

Auxiliary switch, bell alarm switch, shunt trip and undervoltage release relay.



Certificate: 2309926

Master Contract: 163545

Project: 2309926

Date Issued: May 27, 2010

APPLICABLE REQUIREMENTS

CSA Std C22.2 No.5-02 - Moulded Case Circuit Breakers