

Certificate of Compliance

Certificate: 1369437

Master Contract: 163545 (LR 43556)

Project: 1369437

Date Issued: October 28, 2002

Issued to: Cutler-Hammer Inc.
 Sub. of Eaton Corp. d/b/a
 Technology and Quality Center
 170 Industry Dr., RIDC Park W.
 Pittsburgh, PA 15275
 USA
 Attention: Mr. Clive Kimblin

The products listed below are eligible to bear the CSA Mark shown



Issued by:

S. Jeffery, C.E.T.

Authorized by:

Nick Alfano
 Operations Manager

PRODUCTS

CLASS 1432 01 - CIRCUIT BREAKERS - Moulded Case Type

Moulded case circuit breaker, Type MDL frame, Type MDL, MDLB, CMDLB, HMDL, HMDLB, CHMDLB, HMDLDC, 800A, 600V ac and 250V dc in 2 and 3-pole configurations.

Notes: These circuit breakers may be marked with the following high current interrupting ratings.

Breaker Type	Frequency, Hz	Interrupting Capacity (kA)			
		240V ac	480V ac	600V ac	250V dc
MDL, MDLB, CMDLB	50/60	65	50	25	22
HMDL, HMDLB, CHMDLB	50/60	100	65	35	25

Breaker Type	125V dc	Interrupting Capacity (kA)	
		250V dc +	*600V dc +
HMDLDC	42 (1 pole)	42 (2 pole) +	35 (3 pole) +

+ Poles in series.



Certificate: 1369437

Master Contract: 163545 (LR 43556)

Project: 1369437

Date: October 28, 2002

APPLICABLE REQUIREMENTS

- CAN/CSA-C22.2 No. 0-M91 - General Requirements - Canadian Electrical Code, Part II
- CAN/CSA-C22.2 No. 5.1-M91 - Moulded Case Circuit Breakers