

Certificate of Compliance

Certificate Number 20111111 – E7819
Report Reference E7819 – 1986 March 14
Issue Date 2011 November 11

Page 1 of 2



Issued to: **EATON**
1000 CHERRINGTON PKY
MOON TOWNSHIP, PA 15108 USA


This is to certify that representative samples of **Circuit Breakers, Molded Case and Circuit-breaker Enclosures**
Types KD, KI, DK, KDC, KDB, CKDB, HKD, HKDB, CHKDB, KDCB, HKD-DC and KG with ratings of 100-400 A, 600 V ac, 250 V dc in 2, 3 and 4-pole configurations. (See following page for additional model information.)

Have been investigated by Underwriters Laboratories in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: **ANSI/UL 489, "Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures."**

Additional Information: See UL On-line Certification Directory at WWW.UL.COM for additional information.

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

William R. Carney
Director, North American Certification Programs

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.

For questions, please contact a local UL Customer Service Representative at <http://www.ul.com/global/eng/pages/corporate/contactus>

Certificate of Compliance

Certificate Number **20111111 – E7819**
Report Reference **E7819 – 1986 March 14**
Issue Date **2011 November 11**

Page 2 of 2



This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

ELECTRICAL RATINGS:

Interrupting Capacity, kA -

<u>Type</u>	<u>Frequency, Hz</u>	<u>240 V ac</u>	<u>480 V ac</u>	<u>600 V ac</u>	<u>250 V dc</u>
KDC	50/60	200	100	65	22
HKD	50/60	100	65	35	22
KD, KDB	50/60	65	35	25	10
DK	50/60	65	-	-	10
KG	50/60	18	14	10	-
KI	50/60	35	20	-	10

HKDDC - 1 pole, 125 V dc/42 kA. Applies to 2 and 3 pole devices.

HKDDC - 2 poles in series, 250 V dc/50kA. Applies to 2 and 3 pole devices.

HKDDC - 3 poles in series, 600 V dc/42 kA/8 ms.

William R. Carney
Director, North American Certification Programs

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.

For questions, please contact a local UL Customer Service Representative at <http://www.ul.com/global/eng/pages/corporate/contactus>