

# Certificate of Compliance

Certificate Number **20050202-E7819F**  
Report Reference **E7819, July 30, 1992**  
Issue Date **2005 February 2**

Page 1 of 2



*Issued to:* **Cutler-Hammer Inc, Sub. of Eaton Corp.**

170 Industry Dr. - RIDC Park West  
Pittsburgh, PA. 15275 USA

*This is to certify that  
representative samples of*

## **Molded Case Circuit Breakers**


type ND, HND, CND, CHND, CNDC, NGS, NGH, NGC and NDC with a maximum rating of 1200 A, 600 V ac in two, three and four pole configurations.

*Have been investigated by Underwriters Laboratories Inc.® in  
accordance with the Standard(s) indicated on this Certificate.*

*Standard(s) for Safety:* UL 489, "Molded-Case Circuit Breakers, Molded-Case Switches and Circuit Breaker Enclosures."

*Additional Information:* See Addendum For Ratings Information.

**Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.**

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

**Look for the UL Listing Mark on the product**

Issued by: *Susan Amir*  
Susan Amir, Project Handler  
Underwriters Laboratories Inc.

Reviewed by: *Mike Mayes*  
Mike Mayes, lead Engineering Associate  
Underwriters Laboratories Inc.

# Certificate of Compliance

Certificate Number **20050202-E7819F**  
Report Reference **E7819, July 30, 1992**  
Issue Date **2005 February 2**

Page 2 of 2



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## ELECTRICAL RATINGS:

| <u>Type</u> | <u>Freq., Hz.</u> | <u>240 Vac</u> | <u>480 Vac</u> | <u>600 Vdc</u> |
|-------------|-------------------|----------------|----------------|----------------|
| ND, CND     | 50/60             | 65             | 50             | 25             |
| HND, CHND   | 50/60             | 100            | 65             | 35             |
| NDC, CNDC   | 50/60             | 200            | 100            | 50             |
| NGS         | 50/60             | 65             | 50             | 25             |
| NGH         | 50/60             | 100            | 65             | 35             |
| NGC         | 50/60             | 200            | 100            | 50             |

Maximum Continuous Ratings -1200 A.  
The "C" prefix represents a 100% rating.

Issued by: *Susan Amir*  
Susan Amir, Project Handler  
Underwriters Laboratories Inc.

Reviewed by: *Mike Mayes*  
Mike Mayes, lead Engineering Associate  
Underwriters Laboratories Inc.