



CB TEST CERTIFICATE

Ref. Certificate No.

NL-14740

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by: KEMA Quality B.V.

Product: moulded-case circuit-breaker

Applicant: Cutler-Hammer Technology & Quality Center 170 Industry Drive Pittsburg PA United States of America

Manufacturer: Cutler-Hammer Technology & Quality Center 170 Industry Drive Pittsburg PA United States of America

Factory: Eaton Corporation Electrical Group Tuscarwas Road PA 15009, BEAVER United States of America

Rating and principal characteristics: 3 / 4 pole
 $I_e = 250, 300, 320, 350, 400, 500, 600, 630 \text{ A}$
 $U_e = 240 \text{ Vac}, I_{cs} = 85 \text{ kA}, I_{cu} = 85 \text{ kA}$
 $U_e = 415 \text{ Vac}, I_{cs} = 50 \text{ kA}, I_{cu} = 50 \text{ kA}$
 $U_e = 250 \text{ Vdc}, I_{cs} = 22 \text{ kA}, I_{cu} = 22 \text{ kA}$
 $U_{imp} = 8 \text{ kV}, U_i = 690 \text{ V}$

Trade mark (if any): CUTLER-HAMMER

Model/Type reference: L630S

Additional information: Testing procedure: WMT

Sample of product tested to be in conformity with IEC: 60947-2(ed.4)

Test Report Ref. No: 2038004.51 (90 pages)

This CB Test Certificate is issued by the National Certification Body:

KEMA Quality B.V.
Utrechtseweg 310
P.O. Box 5185
6802 ED Arnhem
The Netherlands



Signed by: F.S.Strikwerda

Date of issue: 2008-08-29