



# 中国国家强制性产品认证证书

证书编号: 2008010307312739

## 委托人名称、地址

伊顿电气集团  
1000 Cherrington Parkway Moon Township, PA 15108

## 生产者(制造商)名称、地址

伊顿电气集团  
1000 Cherrington Parkway Moon Township, PA 15108

## 生产企业名称、地址

Cutler Hammer Industries, LTD  
Parque Industrial Itabo KM 18 Carretera SanchezHaina, DR 33166-6503

## 产品名称和系列、规格、型号

塑料外壳式断路器

E125C;Ue:AC240V, AC415V, DC250V(二极串);In:15A, 16A, 20A, 25A, 30A, 32A, 35A, 40A, 45A, 50A, 60A, 63A, 70A, 80A, 90A, 100A, 110A, 125A(热固定磁固定);20A, 25A, 32A, 40A, 50A, 63A, 80A, 100A, 125A(热可调磁固定);过电流脱扣器类型:热磁式;Ics:200/100/42kA;Icu:200/100/42kA 极数:3P、4P;使用类别:A类

## 产品标准和技术要求

GB 14048.2-2008

上述产品符合强制性产品认证实施规则  
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2014年12月16日      有效期至: 2019年12月16日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2008年12月12日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 1060212



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2008010307312739

## NAME AND ADDRESS OF THE APPLICANT

Eaton Electrical Inc.  
1000 Cherrington Parkway Moon Township, PA 15108

## NAME AND ADDRESS OF THE MANUFACTURER

Eaton Electrical Inc.  
1000 Cherrington Parkway Moon Township, PA 15108

## NAME AND ADDRESS OF THE FACTORY

Cutler Hammer Industries, LTD  
Parque Industrial Itabo KM 18 Carretera SanchezHaina, DR 33166-6503

## NAME, MODEL AND SPECIFICATION

Molded case circuit breaker

E125C;Ue:AC240V, AC415V, DC250V(2 poles in  
serial);In:15A, 16A, 20A, 25A, 30A, 32A, 35A, 40A, 45A, 50A, 60A, 63A, 70A, 80A, 90A, 100A, 110A, 125A  
(non-ajustable);20A, 25A, 32A, 40A, 50A, 63A, 80A, 100A, 125A(ajustable only for thermal  
unit);Over current release type:Thermal-magnetic  
type;Ics:200/100/42kA;Icu:200/100/42kA Poles:3P、4P;Utilization Category:A

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.2-2008

This is to certify that the above mentioned products have met the requirements of  
implementation rules for compulsory certification(REF NO. CNCA-C03-02:2014).

Date of issue: Dec.16,2014      Date of expiry: Dec.16,2019

Validity of this certificate is subject to positive result of the regular follow up  
inspection by issuing certification body until the expiry date.

Date of original certification: Dec.12,2008

This certificate can be verified through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Wang Kejiao



**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

Q 1060212