



CSA INTERNATIONAL

Certificate of Compliance

Certificate: 1643119 (LR15024)

Master Contract: 163545

Project: 1643119

Date Issued: 2005/03/16

Issued to: Cutler-Hammer, Inc.

Subsidiary of Eaton Corp., (d/b/a)
Technology & Quality Center
170 Industry Dr
Pittsburgh, PA 15275-1032
USA
Attention: Mr. Kevin Lippert

The products listed below are eligible to bear the CSA Mark shown



Issued by: Steven Jeffrey

Authorized by: Calvin McKenzie, Product
Group Manager

PRODUCTS

CLASS 4652 06 - SWITCHES - Moulded Case

Moulded case switch, Type EGK, 100A and 125A, 347/600 Vac, 480 Vac, 3 Ph,

125/250 Vdc, 2, 3 and 4 pole

Note:

1. The moulded case switch provides no overcurrent protection.



Certificate: 1643119 (LR15024)

Master Contract: 163545

Project: 1643119

Date Issued: 2005/03/16

2. These switches have interrupting ratings shown in Tabel 1 of the Descriptive and Test Report when protected by the fuses as listed.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 5.02 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit -Breaker Enclosures