

# Certificate of Compliance

**Certificate:** 1369436

**Master Contract:** 163545 (LR 43556)

**Project:** 1369436

**Date Issued:** October 30, 2002

**Issued to:** Cutler-Hammer Inc.  
 Sub. of Eaton Corp. d/b/a  
 Technology and Quality Center  
 170 Industry Dr., RIDC Park W.  
 Pittsburgh, PA 15275  
 USA  
 Attention: Mr. Clive Kimblin

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:**

*S. Jeffery* C.E.T.

**Authorized by:**

*Nick Alfano*  
 Operations Manager

## PRODUCTS

CLASS 1432 01 - CIRCUIT BREAKERS - Moulded Case Type

Moulded case circuit breaker, Type J frame, Types J250E, J250S, J250H, JGE, JGS, JGH, 63-250A, 600V ac and 250V dc in 2, 3 and 4-pole configurations.

Notes: These circuit breakers may be marked with the following high current interrupting ratings.

| Type  | Frequency, Hz | Interrupting Capacity (kA) |         |         |         |
|-------|---------------|----------------------------|---------|---------|---------|
|       |               | 240V ac                    | 480V ac | 600V ac | 250V dc |
| JGE   | 50/60         | 65                         | 25      | 18      | 22      |
| J250E | 50/60         | 65                         | 25      | 18      | 22      |
| JGS   | 50/60         | 85                         | 35      | 18      | 22      |
| J250S | 50/60         | 85                         | 35      | 18      | 22      |
| JGH   | 50/60         | 100                        | 65      | 25      | 22      |
| J250H | 50/60         | 100                        | 65      | 25      | 22      |



CSA INTERNATIONAL

**Certificate:** 1369436

**Master Contract:** 163545 (LR 43556)

**Project:** 1369436

**Date:** October 30, 2002

---

**APPLICABLE REQUIREMENTS**

- CAN/CSA-C22.2 No. 0-M91 - General Requirements - Canadian Electrical Code, Part II
- CAN/CSA-C22.2 No. 5.1-M91 - Moulded Case Circuit Breakers