



Certificate of Compliance

Certificate: 2273856

Master Contract: 163545

Project: 2273856

Date Issued: June 14, 2010

Issued to: Eaton Corporation

1000 Cherrington Pkwy
Moon Township, PA 15108
USA
Attention: Lou Grahor

The products listed below are eligible to bear the CSA Mark shown



Steve Jeffery

Issued by: Steve Jeffery

PRODUCTS

CLASS 1432 01 - CIRCUIT BREAKERS - Moulded Case Type

Moulded case circuit breakers, Type LG frame, Types LGC, L630C, LGU, L630U and LGX, L630X, 250-600A, 600V ac max, 3 and 4 pole. Supplied with thermal magnetic trip unit.

1. These circuit breakers may be marked with H1C interrupting ratings as follows:
200,000A at 240V ac. 200,000A at 480V ac. 65,000A at 600V ac. 50,000A at 250V dc.

APPLICABLE REQUIREMENTS

CSA C22.2 No.5-02 Molded Case Circuit Breakers