



Certificate of Compliance

Certificate: 1688126 (LR 43556)

Master Contract: 163545

Project: 2437423

Date Issued: November 21, 2011

Issued to: Eaton Corporation
1000 Cherrington Pkwy
Moon Township, PA 15108
USA
Attention: Lou Grahor

The products listed below are eligible to bear the CSA Mark shown



Steve Jeffrey

Issued by: Steve Jeffrey

PRODUCTS

CLASS 1432 01 - CIRCUIT BREAKERS - Moulded Case Type

Moulded case circuit breaker, Type LG Frame, Types LGE, LGS, LGH, 250-600A, 600V ac, 2, 3, or 4-pole. Supplied with thermal magnetic or electronic trip units. Type LHH, 125-400A, 600Vac, 3-pole

CLASS 1437 01 - CIRCUIT BREAKERS - Accessories

Circuit breaker accessories, wire connecting terminal assembly kits, Cat. Nos.: TA631LK, T631LK, TA632LK, T632LK, TA350LK, and T350LK, with prefixes 1, 2, 3 or 4, for use with the submittor's CSA Certified Type LG Frame circuit breakers.

Notes:

1. Type LG Frame circuit breakers may be marked with the following interrupting ratings.

Type	Frequency, HZ	240V ac	480V ac	600V ac	250V dc	600V dc
LGE	50/60	65	35	18	22	-
LGS	50/60	85	50	25	22	-
LGH	50/60	100	65	35	42 or 50	-
LGE-C	50/60	65	35	18	22	-
LGS-C	50/60	85	50	25	22	-
LGH-C	50/60	100	65	35	42 or 50	-



Certificate: 1688126 (LR 43556)

Master Contract: 163545

Project: 2437423

Date Issued: November 21, 2011

LHH	50/60	100	65	35	42 or 50	-
LGH-DC	-	-	-	-	42 or 50	65
LGS-DC	-	-	-	-	22	50
LGE-DC	-	-	-	-	22	35

2. Suffix letter C may be added to type designations LGE, LGS and LGH to denote suitable for 100% rating.

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 5-02 - Moulded Case Circuit Breakers, Moulded Case Switches, and Circuit Breaker Enclosures.