



# Certificate of Compliance

**Certificate:** 1798990 (LR 15024)

**Master Contract:** 163545

**Project:** 1798990

**Date Issued:** 2007/01/31


**Issued to:** Cutler-Hammer, Inc.

Subsidiary of Eaton Corp., (d/b/a)  
Technology & Quality Center  
170 Industry Dr  
Pittsburgh, PA 15275-1032  
USA  
Attention: Mr. Kevin Lippert


*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:**

  
Steven Jeffrey

**Authorized by:** Oreste Simonetta, Product  
Group Manager



## PRODUCTS

**CLASS 4652 06** - SWITCHES - Moulded Case

Moulded Case Switch, Type LGK, 400 and 600A, 600Vac, 3phase, 250Vdc, 3 and 4Pole.

Note: The moulded case switch provides no overcurrent protection.

Table 1

These switches have the following interruption ratings shown below:



**Certificate:** 1798990 (LR 15024)

**Master Contract:** 163545

**Project:** 1798990

**Date Issued:** 2007/01/31

---

Switch Type Ampere Rating

Max Voltage

I (KA)

Phase

LGK 600 25 3

480 65 3

240 100 3

3

3

**APPLICABLE REQUIREMENTS**

CAN/CSA-C22.2 No 5-02 – Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures



## *Supplement to Certificate of Compliance*

**Certificate:** 1798990

**Master Contract:** 163545

*The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
1798990	2007/01/31	Moulded Case Switches.