

Product Change Notice

PCN#: EE-PCN18007

2/22/2018

CLASSIFICATION OF CHANGE:

Fuseholder specification improvement

DESCRIPTION OF CHANGE:

Update amperage and voltage ratings on HJM panel mount fuseholders manufactured after February 12, 2018.

REASON FOR CHANGE:

Product improvement to allow the HJM fuseholders to be used with higher power density fuse families and be applied in additional applications.

EXPECTED INFLUENCE ON QUALITY, RELIABILITY, AND PERFORMANCE:

There will be no effect on the quality, reliability, or performance other than the increase in power ratings. The HJM fuseholders will now be UL recognized up to 250V and 30A per UL4248-1 in UL file E14853. There is no change in footprint or mounting requirements to achieve this increase in ratings.

PARTS FAMILIES AFFECTED:

Part Number	UPC
HJM	051712718912
HJM-HH	051712719315
BK-HJM	051712107464
BK-HJM-HH	051712107488

TIME SCHEDULE:

HJM family of fuseholders with Eaton manufacturing date code of B06 will have the amperage and voltage markings on device updated to 30A, 250V.

SAMPLE AVAILABILITY:

Available upon request

QUALIFICATION DATA:

Available upon request

ISSUED BY:

Nick Stone
Product Manager – Circuit Protection

CONTACT INFORMATION:

For questions or comments, please contact your local [Eaton sales representative](#).