



FILTER ELEMENT















ALLEN-BRADLEY CONTROL PANEL
COVER VIEW

SIEMENS CONTROL PANEL COVER VIEW

EATON CONTROL PANEL COVER VIEW

SEMI-AUTO CONTROL PANEL

REV

С

- NUIES:

 1. ALL FLANGED PROCESS CONNECTIONS ARE LAP JOINT TYPE, ZINC PLATED CARBON STEEL.

 2. PROCESS FLANGE CONNECTIONS ARE DRILLED TO ANSI, CLASS 150
- OR DIN ND16.

 3. HEADERS MAY BE PIPED AT EITHER END: BLIND FLANGES
- 3. HEADERS MAY BE PIPED AT ETHER FIND, BLIND FLANGES
 (PURCHASER SUPPLIED) REQUIRED FOR OPPOSITE END.

 4. ALL METALLIC WETTED PARTS ARE 316 STAINLESS STEEL.

 5. ALL DIMENSIONS ARE IN INCHES WITH METRIC EQUIVALENTS IN
- BRACKETS [].

 6. FILTER ELEMENTS ARE DESIGNED TO WITHSTAND 150 PSI
 [10.3 BAR] DIFFERENTIAL PRESSURE.
- 7. OPERATING PRESSURE IS 250 PSI (17.24 BAR).
- HYDROSTATIC TEST PRESSURE IS 325 PSI (22.4 BAR). 8. EXTERIOR FINISH:
- TOP COAT: 1 MIL MINIMUM. COLOR: SILVER.



DRAWN BY M. DESJARDINS	
SCALE AS DRAWN	

SCA AS RESTRICTION TITLE RESTRICTED SHEET

EATON FILTRATION, LLC DESIGN CENTER

B

F-2200 EXTERNAL BACKWASH FILTER INLINE RIGHT END VIEW

1 OF 1 SIZE DWG FILENAME PROJECTION DATE THIRD ANGLE 05/13/05 Α F-2200-EB-RE001

THIS DOCUMENT, INCLUDING THE READING AND INFORMATION. THE PROPERTAL AND PROPERTAL AND PROPERTY WITHER TO PERSONS RECEIVED THE DRAWNIN AND JOB TECHNICAL INFORMATION. THIS DOCUMENT, INCLUDING THE READING AND INFORMATION CONTINUED THE PROPERTY OF EATON AND THE RECEIVED A CHARGE THAT THIS DOCUMENT CANNOT BE USED IN ANY MANNER ADVERSE TO THE INTEREST OF EATON AND THAT NO PORTION OF THIS DRAWING MAY BE COPIED WITHOUT THE PETROR WRITED TO SHEET OF EATON, IN THE CASE OF CONFLICTING CONTRACTUAL PROVISIONS, THIS NOTICE SHALL GOVERN THE STATUS OF THIS DOCUMENT.