

SEE F-2200-IB-FP001 FOR TOP VIEW GAUGE, 0-300 PSI [0-21 BAR] AUTOMATIC MANUAL CONTROL PANEL -SEE F-2200-IBR-RE001 FOR RIGHT SIDE VIEW FOR DIMENSION
TABLES SEE
F-2200-IB-DT001 INLET · DRAIN - 3" CONCRETE FOUNDATION 7] [191] TYP 15 [381] TYP

- 1. ALL FLANGED PROCESS CONNECTIONS ARE LAP JOINT TYPE, ZINC PLATED CARBON STEEL.
 2. PROCESS FLANGE CONNECTIONS ARE DRILLED TO ANSI, CLASS 150
- OR DIN ND16.
- 3. HEADERS MAY BE PIPED AT EITHER END; BLIND FLANGES
- (PURCHASER SUPPLIED) REQUIRED FOR OPPOSITE END.

 4. ALL METALLIC WETTED PARTS ARE 316 STAINLESS STEEL.

 5. ALL DIMENSIONS ARE IN INCHES WITH METRIC EQUIVALENTS IN
- BRACKETS []. 6. FILTER ELEMENTS ARE DESIGNED TO WITHSTAND 150 PSI
- [10.3 BAR] DIFFERENTIAL PRESSURE.
 DESIGN PRESSURE IS 250 PSI (17.24 BAR).
- HYDROSTATIC TEST PRESSURE IS 325 PSI (22.4 BAR). 8. EXTERIOR FINISH:
- TOP COAT: 1 MIL MINIMUM. COLOR: SILVER.



EATON FILTRATION, LLC RONNINGEN-PETTER PRODUCTS 9151 SHAVER ROAD PORTAGE, MICHIGAN 49024-6798 USA

THIS DRAWING AND ALL INFORMATION THEREON IS THE PROPERTY OF EATON CORPORATION. IT IS CONFIDENTIAL AND MUST NOT BE MADE PUBLIC. THIS DRAWING IS LOANED SUBJECT TO RETURN ON DEBAND, AND IS NOT TO BE USED DIRECTLY OR INDIRECTLY, IN ANY WAY DETRIMENTAL TO THE INTERESTS OF EATON FILTRATION, LLC.

ENGINEERING APPROVAL .	DRAWN BY M. DESJARDINS	···· = ·				
SALES/MKTG APPROVAL .	scale NONE	INLINE MULTIPLEX FILTER UNIT				
	ENGINEERING SPECIFICATION	05/13/05	size A	DWG FILENAME F-2200-IB-GA001	REV A	