



Ref. Certif. No.

CN48621

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Air Circuit-breakers

Name and address of the applicant

Eaton Electrical Ltd.  
No.2 Louyang Road, SIP Suzhou, Jiangsu Province, 215121, P.R.China

Name and address of the manufacturer

Eaton Electrical Inc.  
1000 Cherrington Parkway Moon Township, PA 15108, USA

Name and address of the factory

Eaton Electrical Ltd.  
2# Lou Yang Road, SIP Suzhou Jiangsu 215121, P.R. China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

See the Appendix

Trademark (if any)

Eaton

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

IZM99N, IZM99H;

Additional information (if necessary may also be reported on page 2)

IEC 60947-2:2016(5th Edition)

A sample of the product was tested and found to be in conformity with

00901-CB2019CQC-087846

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: http://www.cqc.com.cn



Date: Oct.28,2019

Signature:

Lu Mei

IZM99N, IZM99H

Uimp: 12kV;

Ui: 1000V;

Ue: AC440V, AC690V;

In: 4000A, 5000A, 6300A;

Over-current release: Electronic;

Ics: 85kA (IZM99N), 100kA (IZM99H);

Icu: 85kA (IZM99N), 100kA (IZM99H);

Icw: 85kA/1s (IZM99N), 100kA/1s (IZM99H);

3P, 4P;

Suitable for insulation;

50/60Hz;

IP20;

Selectivity category: B;

Accessories with electronic circuits:

Shunt Release

ST: DC24V, DC48V, DC110-125V, DC220-250V, AC110-127V, AC208-240V, AC380V

Undervoltage Release

UVR: DC24V, DC32V, DC48V, DC110-125V, DC220-250V, AC110-127V, AC208-240V

Page 1 of 1

Additional information (if necessary)

Date: Oct.28,2019

Signature:



Lu Mei