

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Air Circuit-breakers

Name and address of the applicant

Eaton Electrical Inc.  
1000 Cherrington Parkway Moon Township, PA 15108, USA

Name and address of the manufacturer

Eaton Electrical Inc.  
1000 Cherrington Parkway Moon Township, PA 15108, USA

Name and address of the factory

Eaton Electrical Ltd.  
2# Lou Yang Road, SIP Suzhou Jiangsu 215121, P.R. China

Note: When more than one factory, please report on page 2

 Additional information on page 2

Ratings and principal characteristics

See the Appendix

Trademark (if any)

Eaton

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

IZM97N, IZM97H, IZM97B, IN97;

Additional information (if necessary may also be reported on page 2)

IEC 60947-2:2016(5th Edition)

A sample of the product was tested and found to be in conformity with

00901-CB2019CQC-087739

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Nov.27,2019

Signature:

Lu Mei

IZM97N,IZM97H,IZM97B,IN97;

Uimp:12kV;

Ui:1000V;

Ue:AC440V,AC690V;

In: 800A,1000A,1250A,1600A,2000A, 2500A,3000A,3200A,4000A;

Over-current release: Electronic;

Ics:66kA(IZM97B),85kA(IZM97N),100kA(IZM97H,AC440V),85kA(IZM97H,AC690V);

Icu: 66kA(IZM97B),85kA(IZM97N),100kA(IZM97H,AC440V),85kA(IZM97H,AC690V);

Icw: 66kA/1s(IZM97B),85kA/1s(IZM97N,IZM97H);

3P,4P;

50/60Hz;

Selectivity category:B;

Electronic Accessories complied with Annex N:

Shunt Release ST: 24VDC,48VDC,110-125VDC/110-127VAC,220-250 VDC/208-240VAC,380VAC

Undervoltage Release UVR: 24VDC,32VDC,48VDC,110-125VDC/110-127VAC, 220-250 VDC/  
208-240VAC, 380VAC


Closing coil: 24VDC,48VDC, 110-125 VDC/110-127 VAC,220-250 DC/208-240VAC

Page 1 of 1

Additional information (if necessary)

Date: Nov.27,2019

Signature:



Lu Mei



Ref. Certif. No.

CN48955

Name of the factory	Address of the factory
1.Eaton Electrical Group	Santana Industrial Park, Road #2 KM 67.6, Arecibo, PR, 00612, USA

Additional information (if necessary)

Date: Nov.27,2019

Signature:

Lu Mei