

IEC**IECEE**

Ref. Certif. No.

CN56135

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Air Circuit-breakers

Name and address of the applicant

Eaton Electrical Inc.
1000 Cherrington Parkway Moon Township, PA 15108, USA

Name and address of the manufacturer

Eaton Electrical Ltd.
No.2 Louyang Road, SIP Suzhou, Jiangsu Province, 215121,
P.R.China

Name and address of the factory

Eaton Electrical Ltd.
No.2 Louyang Road, SIP Suzhou, Jiangsu Province, 215121,
P.R.China

Note: When more than one factory, please report on page 2

 Additional information on page 2

Ratings and principal characteristics

ctfMode
See the Appendix

Trademark / Brand (if any)

Eaton

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

IZM99N, IZM99H, IN99;

Additional information (if necessary may also be reported on page 2)

IEC 60947-2:2016/AMD1:2019; IEC 60947-2:2016(5th Edition)

A sample of the product was tested and found to be in conformity with

00901-CB2021CQC-100295

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Feb.18,2022

Signature:

Xie ZhaoXu

CB 0066811

IZM99N, IZM99H, IN99

Uimp:12kV;

Ui:1000V;

Ue:AC440V,AC690V;

In:4000A,5000A,6300A;

Over-current release: Electronic;

Ics:85kA(IZM99N),100kA(IZM99H);

Icu:85kA(IZM99N),100kA(IZM99H);

Icw:85kA/1s(IZM99N),100kA/1s(IZM99H);

3P,4P;

50/60Hz;

Selectivitycategory:B;

Accessories with electronic circuits:

Shunt Release ST:24VDC,48VDC,110-125VDC/110-127VAC,220-250VDC/208-240VAC,
380VAC;

Undervoltage Release UVR:24VDC,32VDC,48VDC,110-125VDC/110-127VAC, 220-250 VDC/
208-240VAC,380VAC;

Closing coil: Us: 24VDC,48VDC,110-125VDC/110-127VAC,220-250VDC/208-240VAC

Page 1 of 2

Additional information (if necessary)


Date:

Feb.18,2022

Signature:

谢肇煦

Xie ZhaoXu

Type Explanation:IZM 99 H 4-V 63 W

Page 2 of 2

Additional information (if necessary)

Date:

Feb.18,2022

Signature:

Xie ZhaoXu



Ref. Certif. No.

CN56135

Name of the factory	Address of the factory
1.Eaton Electrical Group	Santana Industrial Park, Road #2 KM 67.6, Arecibo, PR, 00612, USA

Additional information (if necessary)

Date: Feb.18,2022

Signature:

Xie ZhaoXu