

IEC**IECEE**

Ref. Certif. No.

CN53061

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

MCCB

Name and address of the applicant

Eaton Electrical Inc.
1000 Cherrington Parkway Moon Township, PA 15108, USA

Name and address of the manufacturer

Eaton Electrical Inc.
1000 Cherrington Parkway Moon Township, PA 15108, USA

Name and address of the factory

Eaton Electrical Ltd.
No.2 Louyang Road, SIP Suzhou, Jiangsu Province, 215121,
P.R.China*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

EATON

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

IZMX16B/N/H, INX16, IZM91B/N/H, IN91

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016/AMD1:2019;IEC 60947-2:2016(5th Edition)

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2019CQC-090228

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: May.18,2021

Signature:

Lu Mei

CB 0062534

182

IZMX16B/N/H, INX16, IZM91B/N/H, IN91

Uimp: 12kV;

Ui: 1000V;

In: 200A,250A,400A,630A,800A,1000A,1250A,1600A;

Over current release: Electronic;

Type B: AC240V:Ics:42kA,Icu:42kA; AC440V:Ics:42kA,Icu:42kA; AC690V:Ics:42kA,Icu:42kA;

Type N: AC240V:Ics:50kA,Icu:85kA; AC440V:Ics:50kA,Icu:50kA; AC690V:Ics:42kA,Icu:42kA;

Type H: AC240V:Ics:65kA,Icu:85kA; AC440V:Ics:50kA,Icu:66kA; AC690V:Ics:42kA,Icu:42kA;

Icw: 42kA/1s;

Icc: 42kA(INX16);

IP20;

Selectivity category: B;CBI-Y(INX16,IN91);

Suitable for isolation;

3P,4P;

50/60Hz;

Accessories with electronic circuits:

Closing coil: Us:

24VDC,48VDC,110-125VDC,220-250VDC,110-127VAC,208-240VAC

Undervoltage release: AC/DC208~240V

Shunt release: AC/DC208~240V

Page 1 of 1

Additional information (if necessary)

Date:

May.18,2021

Signature:



Lu Mei