

CHAMP® SERIES DMV, VMV, LMV STANCHION MOUNT CABLE ADAPTER

INSTALLATION INSTRUCTIONS AND PARTS LIST

SAVE THESE INSTRUCTIONS FOR FUTURE REFERENCE

INSTALLATION

⚠ WARNING

To avoid the risk of fire, explosion, or electric shock, this product should be installed, inspected, and maintained by a qualified electrician only in accordance with all applicable electrical codes.

1. Required components.



Stanchion gland adapter JGA

Stanchion Mount

CGB assembled with cable (supplied by customer)

2. Screw CGB cable gland into JGA adapter. (See table below for JGA to CGB size)



Cat No	Gland Thread
JGA551	1/2 - 14 NPT
JGA552	3/4 - 14 NPT
JGA5520	20mm X 1.5 - 6H
JGA5525	25mm X 1.5 - 6H

3. Assembled adapter with CGB gland.



4. Screw gland assembly into stanchion mount. Secure set screw.



5. Completed assembly



All statements, technical information and recommendations contained herein are based on information and tests we believe to be reliable. The accuracy or completeness thereof are not guaranteed. In accordance with Crouse-Hinds "Terms and Conditions of Sale", and since conditions of use are outside our control, the purchaser should determine the suitability of the product for his intended use and assumes all risk and liability whatsoever in connection therewith.