


PowerWave branch circuit metering and monitoring

New product replacement/old product obsolescence



Wavestar obsolescence FAQs

Wavestar metering for PowerWave track style busway reached its end of life in 2022 and is being replaced by PowerWave branch circuit monitoring (BCM).

FAQs

I have Wavestar monitoring installed. Can I get replacement parts, even though it is no longer available for new installations?

Spare and replacement parts are no longer available for Wavestar metering.

Are PowerWave branch circuit metering parts compatible with my Wavestar installation?

No, PowerWave BCM parts are not backward compatible with Wavestar. If replacement parts are needed, the metering will need to be converted to PowerWave BCM by replacing and ordering the following parts:

- Order new monitored end feed
- Order new monitored tap-off box (TOB)

Note: Please contact your local Eaton sales office for assistance with ordering new parts.

Do I need to replace my existing PowerWave 2 busway?

No, the busway itself does not need to be replaced. Only the end feed and TOB need to be replaced. This is true for both PowerWave 1 and PowerWave 2 installations.

Do I need a specially trained technician to swap out my metering systems?

No, both the PowerWave 2 busway and metering components are designed to be easily installable and scalable.



PowerWave BCM end feed display



PowerWave BCM monitoring

For more information, visit Eaton.com/powerwave



Powering Business Worldwide

Eaton
1000 Eaton Boulevard
Cleveland, OH 44122
United States
Eaton.com

©2024 Eaton
All Rights Reserved
Printed in USA
Publication No. SA017004EN / Z28385
January 2024

Follow us on social media to get the latest product and support information.



Eaton is a registered trademark.

All other trademarks are property of their respective owners.