



 COOPER POWER SYSTEMS DIVISION COMPONENTS & PROTECTIVE EQUIPMENT		TIME-CURRENT CHARACTERISTIC CURVES	
		MINIMUM MELT TIME CURRENT CURVES FOR ISOLATION LINKS IN TRANSFORMER OIL	
DRAWN BY	RJC	CHK'D	Tests made at LOW Volts ac at LOW pf at 25°C with no initial load
DATE	11-6-95	DATE	Standards used as basis for data: ANSI C37.47-1981
REPLACES	2 / 88	REV	02
REQ. NO.	16035		
DWG NO.	42 01559	B	00
			THIS DRAWING WAS PRODUCED ON A CAD SYSTEM, ANY MANUAL REVISION WILL VOID IT.

-MAGNEX ISOLATION LINKS
 CATALOG NO. 3637803B
 CATALOG SECTION 2700
 -BAY-O-NET ASSEMBLY ISOLATION LINK
 CATALOG NO. 3001861A
 CATALOG SECTION 1920
 -ISOLATION LINK ARE RECOMMENDED
 FOR USE WITH EXPULSION BAY-O-NET
 AND MAGNEX INTERRUPTERS.

Reference Data
 R240-91-56
 Page 1