

CERTIFICATE

Issued to:
Applicant:
EATON; CEAG Notlichtsysteme GmbH
Senator-Schwartz-Ring 26
59494 Soest, Germany

Manufacturer/Licensee:
EATON; CEAG Notlichtsysteme GmbH
Senator-Schwartz-Ring 26
59494 Soest, Germany

Product : Self-contained emergency lighting with LEDs
Trade name(s) : EATON, EATON JSB and EATON MENVIER
Type(s)/model(s) : 3583 1-8 h/D LED CGLine+

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60598-1:2015, EN 60598-1:2015/AC:2015, EN 60598-1:2015/AC:2016, EN 60598-2-22:2014, EN 60598-2-22:2014/AC:2015 and EN 60598-2-22:2014/AC:2016-05
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 990758

DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration of the ENEC certification agreement and under the conditions of the ENEC certification agreement.


This certificate is issued on 15 October 2017 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-101345

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



Kate Xu
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Self-contained emergency lighting with LEDs
Trade name(s)	: EATON, EATON JSB and EATON MENVIER
Type(s)/model(s)	: 3583 1-8 h/D LED CGLine+
Rated voltage	: 230 V~
Nature of supply	: ac
Rated frequency	: 50/60 Hz
LED power	: 3 x 1 W
Ambient temperature (maintained)	: -5 °C ...30 °C
Ambient temperature (non maintained)	: 0 °C ...35 °C
Class	: II
Degree of protection	: IP20

TESTS**Test requirements**

EN 60598-1:2015
EN 60598-1:2015/AC:2015
EN 60598-1:2015/AC:2016
EN 60598-2-22:2014
EN 60598-2-22:2014/AC:2015
EN 60598-2-22:2014/AC:2016-05

Test result

The test results are laid down in DEKRA test file 221473600.

Additional Information

- The luminaire contains a LED module which is in compliance with EN 62031:2008 + A1:2013 + A2:2015 (tested as part of the appliance).

The list of components is laid down at test report 2214736.50.

Conclusion

The examination proved that all requirements were met.

Factory locations

EATON; CEAG Notlichtsysteme GmbH
Senator-Schwartz-Ring 26
59494 Soest, Germany

SC Cooper Industries Romania SRL
Zona Industrială Vest
Str. III, Nr. 12
310510 Arad, Romania