



# Kitemark™ Certificate

This is to certify that: Eaton Electrical Systems Ltd

Wheatley Hall Road

Wheatley Doncaster DN2 4NB United Kingdom

Holds Certificate Number: KM 636748

In respect of:

BS EN 62034 Automatic Test Systems
Automatic test systems for battery powered emergency escape lighting

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.

For and on behalf of BSI: Gary Fenton, Global Product Certification Director

First Issued: 2017-02-10 Latest Issue: 2017-05-19

Page: 1 of 3

...making excellence a habit."



### Kitemark™ Certificate

No. KM 636748

### Automatic Test System for Battery Powered Emergency Escape lighting to BS EN 62034:2012.

Product is the CGLine + ATS Eaton 400 71 361 055 (automatic test system)

BSI test reports 8365154 Rev 1 & 8365155 Rev 1

The system is classified as PER.

The test system consists of the following:

The CGLine + ATS Eaton 400 71 361 055 Rated 230V ~ 50/60Hz IP20.

For software version see report.

There are 4 Data loops lines capable of communicating with 200 Emergency Luminaires on each line with a total system capability of 800 Emergency Luminaires.

Also with the following codes JSB 40071361074 and Menvier 40071361440

Only CGLine+ Emergency Luminaires from Kitemark Certificate KM 29086 and CGLine+ Emergency Luminaires certified by DEKRA B.V. are compatible with this test system.

First Issued: 2017-02-10 Latest Issue: 2017-05-19

Page: 2 of 3

# Kitemark™ Certificate

No. KM 636748

#### Automatic Test System for Battery Powered Emergency Escape lighting to BS EN 62034:2012.

Automatic test system variants from CEAG Notlichtsysteme GmbH, Soest Germany

The variants were tested on report number 8680196 and are as follows

Rated 230 V, 50 - 60 Hz, 17-138 mA

Trade Name	Part Number	Description
Eaton	40071361055	CGL + Web Controller
	40071361184	CGL + Web Controller Connection Box
	40071361275	CGL + Wi-Fi Connection Box
Menvier	40071361440	CGL + Web Controller
	40071361441	CGL + Web Controller Connection Box
	40071361442	CGL + Wi-Fi Connection Box
JSB	40071361074	CGL + Web Controller
	40071361430	CGL + Web Controller Connection Box
	40071361431	CGL + Wi-Fi Connection Box

Automatic test system variants from Cooper Securite S.A.S. Riom, France

The models were tested on report number 8680224 and are as follows

Rated 230 V, 50 - 60 Hz, 50-160 mA

Trade Name	Part Number	Description	
Eaton	40071361056	CGL + Web Touchscreen controller	
	40071361083	CGL + CGVision Touchscreen S/controller	
	40071361084	CGL + CGVision Touchscreen G/controller	
Menvier	40071777999-M	CGL + Web Touchscreen controller	
	40071777998-M	CGL + CGVision Touchscreen S/controller	
	40071777997 <b>-</b> M	CGL + CGVision Touchscreen G/controller	
JSB	40071777999 <b>-</b> J	CGL + Web Touchscreen controller	
	40071777998 <b>-</b> J	CGL + CGVision Touchscreen S/controller	
	40071777997 <b>-</b> J	CGL + CGVision Touchscreen G/controller	

First Issued: 2017-02-10 Latest Issue: 2017-05-19

Page: 3 of 3

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated online.