

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Luminaire for emergency lighting with LED light source
Name and address of the applicant	Cooper Sécurité S.A.S. ZAC de la Gravière, Rue Beethoven, Parc Européen d' Entreprise RII, 63200 Riom France France
Name and address of the manufacturer	Cooper Sécurité S.A.S. ZAC de la Gravière, Rue Beethoven, Parc Européen d' Entreprise RII, 63200 Riom France France
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 SC Cooper Industries Romania SRL Zona Industriala Vest Str.III, Nr.12 310510 Arad Romania
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	230 Vac, 50-60 Hz, class II, IP42, IK04 Crystal Way 20m CGLine+ (L,R,D,U) - LUM17122U: 2,5 W Crystal Way 30m CGLine+ (L,R,D,U) - LUM17124U: 4,2 W
Trademark (if any)	EATON
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	Crystal Way 20m CGLine+ (L,R,D,U) - LUM17122U Crystal Way 30m CGLine+ (L,R,D,U) - LUM17124U
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60598-1:2014, IEC 60598-2-22:2014 National differences: EU Group Differences
As shown in the Test Report Ref. No. which forms part of this Certificate	2221058.52

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands