

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Emergency lighting luminaire with LED light source
Name and address of the applicant	COOPER SECURITE SAS Parc Européen d' Entreprise RII Rue Beethoven - BP 10184, 63204 Riom France
Name and address of the manufacturer	COOPER SECURITE SAS Parc Européen d' Entreprise RII Rue Beethoven - BP 10184, 63204 Riom 63200 RIOM France
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 SC Cooper Industries Romania SRL Zona Industriala Vest Str. III, Nr.12 310510 Arad Romania
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	230 V, 50/60 Hz, Ta= 5...25 °C, class II, IP20
Trademark (if any)	EATON
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	Halo-Pack 2 /HPLED3H
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2 This certificate replaces NL-49901 dated 2018-01-25 due to update to latest edition of IEC 60598-2-22 and IEC 62031
A sample of the product was tested and found to be in conformity with	IEC 60598-1:2014, IEC 60598-1:2014/AMD1:2017, IEC 60598-2-22:2014, IEC 60598-2-22:2014/AMD1:2017 National differences: EU Group Differences
As shown in the Test Report Ref. No. which forms part of this Certificate	2227765.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands