

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Emergency lighting luminaire with LED light source
Name and address of the applicant	Cooper Securite SAS Parc Européen d' Entreprise RII, Rue Beethoven - BP 10184, 63204 Riom France
Name and address of the manufacturer	Cooper Securite SAS Parc Européen d' Entreprise RII, Rue Beethoven - BP 10184, 63204 Riom France
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 Cooper Securite SAS Parc Européen d' Entreprise RII, Rue Beethoven - BP 10184, 63204 Riom France
<i>Note: When more than one factory, please report on page 2</i>	
Ratings and principal characteristics	230 Vac, 50/60Hz, Class II, IP42 / IP65, ta 5 °C...35 °C
Trademark (if any)	EATON
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	MATRIX series and MATRIX DYNAMIQUE ACTIF series. See "general product information".
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60598-1:2014, IEC 60598-1:2014/AMD1:2017, IEC 60598-2-22:2014, IEC 60598-2-22:2014/AMD1:2017 National differences: EU Group Differences
As shown in the Test Report Ref. No. which forms part of this Certificate	2222710.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands