

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Luminaire for emergency lighting with LED light source

Name and address of the applicant

COOPER UNIVEL S.A.  
88 Thessaloniki Street  
P.O.BOX 48, 60100 Katerini  
Greece

Name and address of the manufacturer

Cooper Csa Srl  
Via San Bovio,3 – Edificio Y  
20090 Segrate (MI)  
Italy

Name and address of the factory

*Note: When more than one factory, please report on page 2* [Additional information on page 2](#)  
COOPER INDUSTRIES ROMANIA S.R.L.  
Zona Industrială NV  
Strada III, Nr. 12  
310510 Arad  
Romania

Ratings and principal characteristics

230 V, 50/60 Hz, 35 mA, LED module,  
duration 60 - 90 - 180 minutes. Class II; IP20,  
Type of installation: ceiling  
Refers to CB Test Report for the entire list of rating covered by the  
certificate

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

ESM-AT, ESC, ESC-AUT, ESC-CGL  
ESM-AT-3H, ESC-3H-AUT, ESC-3H, ESC-3H-CGL,  
ESMAINS

Additional information (if necessary may also be reported on page 2)

 [Additional information on page 2](#)

A sample of the product was tested and found to be in conformity with

IEC 60598-1:2014, IEC 60598-2-22:2014

As shown in the Test Report Ref. No. which forms part of this Certificate

National differences:  
EU Group Differences  
3505689,50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, NetherlandsFirmato digitalmente da  
MASSIMILIANO TRIULZI