


**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product	Luminaire for emergency lighting with LED light source
Name and address of the applicant	COOPER SECURITE SAS Rue Beethoven 63204 Riom France
Name and address of the manufacturer	Cooper Csa S.r.l. Via San Bovio,3 – Edificio Y 20090 Segrate (MI) Italy
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 Digital Lighting Dongguan Co Ltd Xinmin Road, Xinmin District Chang 'an Town 523879 China
<i>Note: When more than one factory, please report on page 2</i>	
Ratings and principal characteristics	230 V, 50/60 Hz, LED modules, autonomy 60 – 180 minutes. Class II; IP42 or IP65 Type installation: ceiling / wall / recessed ceiling / recessed wall Refers to CB Test Report for the entire list of rating covered by the certificate
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	Series : SafeLite, Starled & Zeta4
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2 The luminaire can be mounted on the recessed ceiling by means the accessories: SL2RB, SL3RB The luminaire can be mounted on the recessed wall by means the accessory SL2WB
A sample of the product was tested and found to be in conformity with	IEC 60598-1:2014, IEC 60598-2-22:2014 National differences: EU Group Differences
As shown in the Test Report Ref. No. which forms part of this Certificate	3505045.50

This CB Test Certificate is issued by the National Certification Body

Meander 1051, NL-6825 MJ Arnhem, Netherlands
DEKRA Certification B.V.

