LPCB

This is to Certify

COOPER INDUSTRIES INC

Wheatley Hall Road, Doncaster, South Yorkshire DN2 4NB

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix.

DF6000 and CF2000 Analogue addressable control and indicating equipment

which have complied with the requirements of the following:

EN 54-2: 1997 EN 54-4: 1997

Certificate No: 714a

Issue Number: 06

Date of Issue: 03 December 2012

Signed for and on behalf of LPCB

LPCB ON CERTIFICATION OF THE PROPERTY OF THE P



E MATTIE-SULEIMAN



Appendix to Certificate

Certificate No: 714a

COOPER INDUSTRIES INC

Certified Products

LPCB Ref. No.

DF6000 Analogue addressable 2 and 4 Loop control and indicating equipment

714a/01

Incorporating the following units:

ADF6 Back Assembled back box YPCB2153 Motherboard PCB

YPCB2147 PSU PCB

YPCB2148 2 Loop Card (2 off) ADF6Screen Touch Screen

YPCB2185 Complete Display + Micro PCB

ADF6 DISPCOVER
ADF6FACIA
ADF6PRINTDOOR
Display PCB Cover
Front Moulding
Printer Door Moulding

BAT-NP12-12 Batteries (2 off)
ADF6HINGE Door Hinges

ADF6OPFACIA Optional Anti Tamper Cover

ADF6PRINTER Printer

YPCB2187 Fire Brigade Interface

Certified with the following options with requirements from EN 54-2:

- 7.8 Output to fire alarm device(s)
- 7.9 Output to fire alarm routing equipment
- 7.10 Output to automatic fire protection equipment
- 7.11 Delays to the actioning of outputs fire alarm devices and fire routing equipment
- 7.12 Coincidence detection
- 7.13 Alarm counter
- 8.9 Output to fault warning routing equipment
- 9.5 Disablement of each address point
- 10 Test condition

For details of Cross-Listed products and alternative branding please see page 4

Appendix Issue No: 06

Page: 2 of 4

Date of Issue: 03 December 2012

Signed for and on behalf of LPCB

E MATTIE-SULEIMAN





Appendix to Certificate

Certificate No: 714a

COOPER INDUSTRIES INC

Products

LPCB Ref. No.

CF2000 Analogue addressable 2 Loop control and indicating equipment

714a/02

Incorporating the following units:

PR202-50-2209 Power supply board PR202-50-2206 Main motherboard PR202-50-2205 Display board

Certified with the following options with requirements from EN 54-2:

7.14 Output to fire alarm device(s)

7.15 Output to fire alarm routing equipment

7.16 Output to automatic fire protection equipment

7.17 Delays to the actioning of outputs fire alarm devices and fire routing equipment

7.18 Coincidence detection

7.19 Alarm counter

8.10 Output to fault warning routing equipment

9.5 Disablement of each address point

10 Test condition

For details of Cross-Listed products and alternative branding please see page 4

Appendix Issue No: 06

Page: 3 of 4

Date of Issue: 03 December 2012

Signed for and on behalf of LPCB

E MATTIE-SULEIMAN







Appendix to Certificate

Certificate No: 714a

COOPER INDUSTRIES INC

ALTERNATIVE MODEL NUMBERS AND LABELLING

 LPCB Ref. No.
 Model No.
 Alternative Model No.
 Labelled
 Distributor Cert No.

 714a/01
 DF6000
 CF3000
 Cooper fire
 714a-(cl-1)

 714a/01
 DF6000
 FX6000
 JSB
 714a-(cl-2)

For details of Cross-Listed products and alternative branding please see page 4

Appendix Issue No: 06

Page: 4 of 4

Date of Issue: 03 December 2012

Signed for and on behalf of LPCB

E MATTIE-SULEIMAN



