

## Certificate of Product Approval

Certificate Number: 714s

Issue: 01

### Cooper Lighting & Safety Ltd

Wheatley Hall Road  
Doncaster  
South Yorkshire  
DN2 4NB  
United Kingdom



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

#### Products

##### Visual Alarm Devices

CAB482WS, MAB882WS, FXN582WS, CAB482WD, MAB882WD, FXN582WD, CAB492WS, MAB892WS, FXN592WS, CAB492WD, MAB892WD, FXN592WD, CAB482CS, MAB882CS, FXN582CS, CAB492CS, MAB892CS, FXN592CS

#### Standards

**EN 54-23:2010**  
**EN 54-17:2005**

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB

P Halligan  
Verifier

07 October 2016  
Date of Issue

07 October 2016  
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)



## Appendix to Certificate No: 714s Cooper Lighting & Safety Ltd

Issue: 01

Certified Product	Description	LPCB Ref.No.
CAB482WS	Addressable Type A Red Light Flash Wall VAD with Isolator (Red Body) (Shallow Base) Notes: 1. Meets the requirements of EN 54-23 at the following: - Category W-2.4-7.5 + W-2.4-2.5 - Flash rate 0.5Hz or 1Hz - Synchronisation - Red LED - Clear Lens	714s/01
MAB882WS	Addressable Type A Red Light Flash Wall VAD with Isolator (Red Body) (Shallow Base) (Menvier) Notes: 1. Meets the requirements of EN 54-23 at the following: - Category W-2.4-7.5 + W-2.4-2.5 - Flash rate 0.5Hz or 1Hz - Synchronisation - Red LED - Clear Lens	714s/01
FXN582WS	Addressable Type A Red Light Flash Wall VAD with Isolator (Red Body) (Shallow Base) (JSB) Notes: 1. Meets the requirements of EN 54-23 at the following: - Category W-2.4-7.5 + W-2.4-2.5 - Flash rate 0.5Hz or 1Hz - Synchronisation - Red LED - Clear Lens	714s/01

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

P Halligan  
Verifier

07 October 2016  
Date of Issue

07 October 2016  
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)




## Appendix to Certificate No: 714s Cooper Lighting & Safety Ltd

Issue: 01

Certified Product	Description	LPCB Ref.No.
CAB482WD	Addressable Type A/B Red Light Flash Wall VAD with Isolator (Red Body) (Shallow Base/Deep Base) Notes: 1. Meets the requirements of EN 54-23 at the following: - Category W-2.4-7.5 + W-2.4-2.48 - Flash rate 0.5Hz or 1Hz - Synchronisation - Red LED - Clear Lens	714s/02
MAB882WD	Addressable Type A/B Red Light Flash Wall VAD with Isolator (Red Body) (Shallow Base/Deep Base) (Menvier) Notes: 1. Meets the requirements of EN 54-23 at the following: - Category W-2.4-7.5 + W-2.4-2.48 - Flash rate 0.5Hz or 1Hz - Synchronisation - Red LED - Clear Lens	714s/02
FXN582WD	Addressable Type A/B Red Light Flash Wall VAD with Isolator (Red Body) (Shallow Base/Deep Base) (JSB) Notes: 1. Meets the requirements of EN 54-23 at the following: - Category W-2.4-7.5 + W-2.4-2.48 - Flash rate 0.5Hz or 1Hz - Synchronisation - Red LED - Clear Lens	714s/02

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

P Halligan  
Verifier

07 October 2016  
Date of Issue

07 October 2016  
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)




## Appendix to Certificate No: 714s Cooper Lighting & Safety Ltd

Issue: 01

Certified Product	Description	LPCB Ref.No.
CAB492WS	Addressable Type A White Light Flash Wall VAD with Isolator (Red Body) (Shallow Base) Notes: 1. Meets the requirements of EN 54-23 at the following: - Category W-2.4-7.5 + W-2.4-2.5 - Flash rate 0.5Hz or 1Hz - Synchronisation - White LED - Clear Lens	714s/03
MAB892WS	Addressable Type A White Light Flash Wall VAD with Isolator (Red Body) (Shallow Base) (Menvier) Notes: 1. Meets the requirements of EN 54-23 at the following: - Category W-2.4-7.5 + W-2.4-2.5 - Flash rate 0.5Hz or 1Hz - Synchronisation - White LED - Clear Lens	714s/03
FXN592WS	Addressable Type A White Light Flash Wall VAD with Isolator (Red Body) (Shallow Base) (JSB) Notes: 1. Meets the requirements of EN 54-23 at the following: - Category W-2.4-7.5 + W-2.4-2.5 - Flash rate 0.5Hz or 1Hz - Synchronisation - White LED - Clear Lens	714s/03

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

P Halligan  
Verifier

07 October 2016  
Date of Issue

07 October 2016  
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)




## Appendix to Certificate No: 714s Cooper Lighting & Safety Ltd

Issue: 01

Certified Product	Description	LPCB Ref.No.
CAB492WD	Addressable Type A/B White Light Flash Wall VAD with Isolator (Red Body) (Shallow Base/Deep Base) Notes: 1. Meets the requirements of EN 54-23 at the following: - Category W-2.4-7.5 + W-2.4-2.5 - Flash rate 0.5Hz or 1Hz - Synchronisation - White LED - Clear Lens	714s/04
MAB892WD	Addressable Type A/B White Light Flash Wall VAD with Isolator (Red Body) (Shallow Base/Deep Base) (Menvier) Notes: 1. Meets the requirements of EN 54-23 at the following: - Category W-2.4-7.5 + W-2.4-2.5 - Flash rate 0.5Hz or 1Hz - Synchronisation - White LED - Clear Lens	714s/04
FXN592WD	Addressable Type A/B White Light Flash Wall VAD with Isolator (Red Body) (Shallow Base/Deep Base) (JSB) Notes: 1. Meets the requirements of EN 54-23 at the following: - Category W-2.4-7.5 + W-2.4-2.5 - Flash rate 0.5Hz or 1Hz - Synchronisation - White LED - Clear Lens	714s/04

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

P Halligan  
Verifier

07 October 2016  
Date of Issue

07 October 2016  
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)




## Appendix to Certificate No: 714s Cooper Lighting & Safety Ltd

Issue: 01

Certified Product	Description	LPCB Ref.No.
CAB482CS	Addressable Type A Red Light Flash Ceiling VAD with Isolator (Red Body) (Shallow Base) Notes: 1. Meets the requirements of EN 54-23 at the following: - Category C-3.0-7.5 + C-3.0-2.5 - Flash rate 0.5Hz or 1Hz - Synchronisation - Red LED - Clear Lens	714s/05
MAB882CS	Addressable Type A Red Light Flash Ceiling VAD with Isolator (Red Body) (Shallow Base) (Menvier) Notes: 1. Meets the requirements of EN 54-23 at the following: - Category C-3.0-7.5 + C-3.0-2.5 - Flash rate 0.5Hz or 1Hz - Synchronisation - Red LED - Clear Lens	714s/05
FXN582CS	Addressable Type A Red Light Flash Ceiling VAD with Isolator (Red Body) (Shallow Base) (JSB) Notes: 1. Meets the requirements of EN 54-23 at the following: - Category C-3.0-7.5 + C-3.0-2.5 - Flash rate 0.5Hz or 1Hz - Synchronisation - Red LED - Clear Lens	714s/05

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

P Halligan  
Verifier

07 October 2016  
Date of Issue

07 October 2016  
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)




## Appendix to Certificate No: 714s Cooper Lighting & Safety Ltd

Issue: 01

Certified Product	Description	LPCB Ref.No.
CAB492CS	Addressable Type A White Light Flash Ceiling VAD with Isolator (Red Body) (Shallow Base) Notes: 1. Meets the requirements of EN 54-23 at the following: - Category C-3.0-7.5 + C-3.0-2.5 - Flash rate 0.5Hz or 1Hz - Synchronisation - White LED - Clear Lens	714s/06
MAB892CS	Addressable Type A White Light Flash Ceiling VAD with Isolator (Red Body) (Shallow Base) (Menvier) Notes: 1. Meets the requirements of EN 54-23 at the following: - Category C-3.0-7.5 + C-3.0-2.5 - Flash rate 0.5Hz or 1Hz - Synchronisation - White LED - Clear Lens	714s/06
FXN592CS	Addressable Type A White Light Flash Ceiling VAD with Isolator (Red Body) (Shallow Base) (JSB) Notes: 1. Meets the requirements of EN 54-23 at the following: - Category C-3.0-7.5 + C-3.0-2.5 - Flash rate 0.5Hz or 1Hz - Synchronisation - White LED - Clear Lens	714s/06

### Bases

Shallow Base (Type A)  
Deep Base (Type B)

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

P Halligan  
Verifier

07 October 2016  
Date of Issue

07 October 2016  
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)


