

Eaton Electrical Systems Ltd
Wheatley Hall Road, Doncaster,
South Yorkshire DN2 4NB, UK
Tel: +44 (0)1302 303350
Fax: +44 (0)1302 303340

Email: Firetechsupport@eaton.com Web: www.cooperfire.com

DECLARATION OF CONFORMITY

Eaton Electrical Systems Ltd. We, Wheatley Hall Road, Doncaster, South Yorkshire, United Kingdom. DN2 4NB

declare under our sole responsibility that the product(s) CZMU352, MIU871, FXN512 (for Fire Detection & Fire Alarm Systems)	
SC Cooper Industries Romania SRL, Zona Indu Romania	striala NV, Str.III, NR12, Arad, 310510,
is (are) in conformity with the following standard(s) or other normative document(s) EN 61000-6-3:2007 + A1:2011 (EMC), EN 50130-4:2011 (EMC) EN 50581:2012 (RoHS)	
when used in the following applications & conditions:	Fire Detection & Alarm Systems
following the provisions of the directive(s):	2014/30 EU - EMC 2011/65/EU - RoHS
20 th April 2016	Olan I 6le
Date of Declaration	Ian P Stokes, Technical Director

Year of affixing the CE-marking: 2011

Registered in England No. 1342230. Registered Office: Jephson Court, Tancred Close, Royal Leamington Spa, Warwickshire. CV31 3RZ