Eaton Electrical Products Ltd

Llantarnam Park, Cwmbran, South Wales, NP44 3AW Tel: +44 (0) 1633 628500 Fax: +44 (0) 1633 866346 Emai: Firecustomerservices@eaton.com

Web: www.eaton.com



DECLARATION OF PERFORMANCE

No DoP0074

Unique identification code of the product-type:		
CXL/GP/R/WP		
Intended use/es:		
Fire detection and fire alarm systems		
Manufacturer:		
Eaton Electrical Products Ltd, Llantarnam Park, Cwmbran, South Wales, NP44 3AW, United Kingdom		
Authorised representative:		
Not Applicable		
System/s of AVCP:		
System 1		
Harmonised standard/s:		
EN54-11:2001+A1:2005		
Notified body/ies:		
BRE Global Ltd, Bucknalls Lane, Watford, Hertfordshire, WD25 9XX, United Kingdom (0832-CPD-0744)		

Eaton Electrical Products Ltd

Llantarnam Park, Cwmbran, South Wales, NP44 3AW Tel: +44 (0) 1633 628500 Fax: +44 (0) 1633 866346

Emai: Firecustomerservices@eaton.com

Web: www.eaton.com



Declared performance/s:

Essential Characteristics	Performance	Harmonized Technical Specification
		EN54-11:2001 + A1:2005
Nominal activation conditions/Sensitivity, Performance under fire conditions	Pass	4.3.2, 4.4, 4.7.1, 4.7.4, 5.2, 5.3
Operational reliability	Pass	4.2, 4.3.1, 4.5, 4.6, 4.7.2, 4.7.3, 4.7.5, 4.8, 5.4, 5.5
Durability Of Operational Reliability, Temperature Resistance	Pass	5.7, 5.9
Durability Of Operational Reliability, Vibration Resistance	Pass	5.14 to 5.17
Durability Of Operational Reliability, Humidity Resistance	Pass	5.10, 5.12
Durability Of Operational Reliability, Corrosion Resistance	Pass	5.11, 5.13
Durability Of Operational Reliability, Electrical Stability	Pass	5.6, 5.18

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulations (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for an on behalf of the manufacturer by:

Name: Mr Philip Williams (Approvals Manager)

Signed: PJ Wall

Place: Cwmbran Date: 15th July 2019