Intertek Intertek Intertek Intertek Intertek Inter-

Certificate of Constancy of Performance 0359-CPR-00438



In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation), this certificate applies to the construction product(s).

Product(s): Cooper Lighting and Safety Limited Conventional and BiWire Ultra

Sounder Beacon

Produced by or for: Cooper Fulleon Limited

Llantarnam Park, Cwmbran, GWENT, NP44 3AW, United Kingdom

Produced in the Cooper Fulleon Limited (CPRCOOUK.1)

manufacturing plant(s): Llantarnam Park, Cwmbran, GWENT, NP44 3AW, United Kingdom

Intended use: Fire Safety

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the

standard(s):

EN54-3:2001+A1:2002+A2:2006

Fire detection and fire alarm systems – Fire alarm devices – Sounders

EN54-23:2010

Fire detection and fire alarm systems – Fire alarm devices – Visual alarm devices

under system 1 are applied and that the product(s) fulfils all the prescribed requirements set out above.

This certificate was first issued on **15/04/2015** and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly, unless suspended or withdrawn by the product certification body. A review of the product(s) and compliant standard(s) will be carried out after 5 years to ensure continued compliance.

Notified Body 0359

Intertek Testing & Certification Limited Cleeve Road, Leatherhead

Surrey, KT22 7SB Tel: + 44 (0)1372 370900

www.intertek.com

Fax: +44 (0)1372 370977 E-mail: cpd.uk@intertek.com Oliver Richardson
Operations Manager

1

Date 15/04/2015 Issue 1

Review date 15/04/2019

Registered No 3272281 Academy Place, 1-9 Brook Street, Brentwood, Essex, CM14 5NQ, United Kingdom



Appendix to Certificate of Constancy of Performance 0359-CPR-00438

The details and conditions of use for the Cooper Lighting and Safety Limited Conventional and BiWire sounder beacon placed on the market by;

Cooper Fulleon Limited

Llantarnam Park, Cwmbran, GWENT, NP44 3AW, United Kingdom

To be used in accordance with the supplier's installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (where applicable):

Products compliant with EN54-3:2001+A1:2002+A2:2006

Variant Manufacturing Description

Location

SQG3-23 CPRCOOUK.1 Conventional / BiWire Ultra sounder beacon

Products compliant with EN54-23:2010

Variant Manufacturing Description

Location

SQG3-23 CPRCOOUK.1 Conventional / BiWire Ultra sounder beacon

Bases / Base Plates:

Variant26-280

Description
Fixing plate

Accessories:

Variant Description 26-305-027C Cover Plate

Intertek Testing & Certification Limited, Cleeve Road, Leatherhead, Surrey, KT22 7SB Tel: + 44 (0)1372 370900, Fax: +44 (0)1372 370977, E-mail: cpd.uk@intertek.com

0359-CPR-00438 Issue 1

www.intertek.com

Registered No 3272281 Academy Place, 1-9 Brook Street, Brentwood, Essex, CM14 5NQ, United Kingdom



Compliant settings: EN54-3:2001+A1:2002+A2:2006

The sounders and sounder beacons are compatible with the following tones and volume settings:-

	Models SQG3-23				
Tone	Volume	Switch A (Tone)	Switch B (Volume)		
Continuous (910Hz)	High and Low Volume	1=On 2=On	1 – Off=High On=Low		
Bell (1440Hz)	High and Low Volume	1=Off 2=On	1 – Off=High On=Low		
Alternating (610/910Hz)	High and Low Volume	1=On 2=Off	1 – Off=High On=Low		

Compliant settings: EN54-23:2010

Model SQG3-23 is compliant with Open Class.

Limitations:

When mounted as a ceiling mount device, the maximum downwards coverage is declared by the
manufacturer to be 90 cm from the front face of the unit on products SQG3-23. The coverage shape
emitted by the subject products does not approximate to either a cylinder when ceiling mounted or a
cuboid when wall mounted. The declaration of downward coverage is defined within the
manufacturer's installation instructions, 25-12947-C dated September 2014.

Conditions of use:

- 1. The sounder beacons listed are approved as Category 'O' devices as defined in EN54-23:2010 Clause 4.3.1.4. These products have a specific coverage volume and shape and reference should be made to the manufacturer's installation instructions to determine the suitability of the product for the intended application.
- 2. All variants are suitable for indoor use only.
- 3. The products listed are designed to operate as part of a conventional system or a BiWire Ultra system and should be used with suitable compatible control and indicating equipment.
- 4. Reference is made to the 'Limitations' section on this certificate.

General Notes:

- 1. Evaluated under Intertek project number 101597042
- 2. The sounder beacons did not meet the requirements of Clause 5.3.2 Variation in luminous intensity as a reading could not be taken at the 90' angle. Readings were taken at an angle of 45' to verify that the variation of luminous intensity requirement was met.
- 3. <u>CE or other type approval is made or inferred outside of the attestation of conformity and the product performance as stipulated on this certificate.</u>

Intertek Testing & Certification Limited, Cleeve Road, Leatherhead, Surrey, KT22 7SB Tel: + 44 (0)1372 370900, Fax: +44 (0)1372 370977, E-mail: cpd.uk@intertek.com

0359-CPR-00438 Issue 1

www.intertek.com

Registered No 3272281 Academy Place, 1-9 Brook Street, Brentwood, Essex, CM14 5NQ, United Kingdom



Appendix to Certificate of Constancy of Performance 0359-CPR-00438 (continued)

Table of performance for EN54-3:2001+A1:2002+A2:2006 Harmonised technical specification						
Essential characteristics	Performance	Clauses	Notes			
Performance under fire conditions	Pass	4.2, 4.3, 5.2, 5.3, C.3.1, C.3.2, C.5.1, C.5.2, C.5.3	a), b)			
Operational reliability	Pass	4.4, 4.5, 4.6, 5.4, C4				
Durability of operational reliability: temperature resistance	Pass	5.5, 5.6, 5.7, 5.8, 5.9	C)			
Durability of operational reliability: humidity resistance	Pass	5.8, 5.9, 5.10	C)			
Durability of operational reliability: corrosion resistance	Pass	5.11				
Durability of operational reliability: shock and vibration resistance	Pass	5.12, 5.13, 5.14, 5.15				
Durability of operational reliability: electrical stability	Pass	5.16				
Durability of operational reliability: resistance to ingress	Pass	5.17				

Notes;

- a) Clauses C.3, C.4, C.5.1, C.5.2 and C.5.3 are applicable only to devices having a voice alarm function. No assessment was carried out against these clauses.
- b) Clauses C.3.2 and C.5.3 are applicable only to devices having a voice alarm function with synchronisation. No assessment was carried out against these clauses.
- c) Clauses 5.6 and 5.10 are applicable only to devices suitable for outdoor use. No assessment was carried out against these clauses.

Intertek Testing & Certification Limited, Cleeve Road, Leatherhead, Surrey, KT22 7SB Tel: + 44 (0)1372 370900, Fax: +44 (0)1372 370977, E-mail: cpd.uk@intertek.com

0359-CPR-00438 Issue 1

www.intertek.com

Registered No 3272281 Academy Place, 1-9 Brook Street, Brentwood, Essex, CM14 5NQ, United Kingdom



Appendix to Certificate of Constancy of Performance 0359-CPR-00438 (continued)

Table of performance for EN54-23:2010 Harmonised technical specification					
Essential characteristics	Performance	Clauses	Notes		
Operational reliability:					
Duration of operation	Pass	4.2.1			
Provision for external conductors	Pass	4.2.2			
Flammability of materials	Pass	4.2.3			
Enclosure protection	Pass	4.2.4			
Access	Pass	4.2.5			
Manufacturer's adjustment	Pass	4.2.6			
On-site adjustment of behaviour	Pass	4.2.7			
Requirements for software controlled devices	Pass	4.2.8			
Performance parameters under fire condition:					
Coverage volume	Pass	4.3.1	a)		
Variation of light output	NPD	4.3.2	b)		
Minimum and maximum light intensity	Pass	4.3.3	,		
Light colour	White	4.3.4			
Light temporal pattern and frequency of flashing	Pass / 0.5Hz	4.3.5			
Marking and data	Pass	4.3.6			
Synchronization (option with requirements)	Pass	4.3.7			
Durability;					
Temperature resistance:					
Dry heat (operational)	Pass	4.4.1.1			
Dry heat (endurance)	NPD	4.4.1.2	c)		
Cold (operational)	Pass	4.4.1.3			
Humidity resistance:					
Damp heat, cyclic (operational)	Pass	4.4.2.1			
Damp heat, steady state (endurance)	Pass	4.4.2.2			
Damp heat, cyclic (endurance)	NPD	4.4.2.3	c)		
Shock and vibration resistance					
Shock (operational)	Pass	4.4.3.1			
Impact (operational)	Pass	4.4.3.2			
Vibration (operational)	Pass	4.4.3.3			
Vibration (endurance)	Pass	4.4.3.4			
Corrosion resistance:					
SO2 corrosion (endurance)	Pass	4.4.4			
Electrical stability					
EMC, immunity (operational)	Pass	4.4.5			

Notes:

- a) Clause 4.3.1 Reference should be made to the manufacturer's data regarding coverage volume.
- b) Clause 4.3.2 NPD declared against this clause as a reading could not be taken at the stated angle of 90°. A reading was taken at 45° to verify that the variation was within limits.
- c) Clauses 4.4.1.2 and 4.4.2.3 are applicable only to devices suitable for outdoor use. No assessment was carried out against these clauses.

Intertek Testing & Certification Limited, Cleeve Road, Leatherhead, Surrey, KT22 7SB Tel: + 44 (0)1372 370900, Fax: +44 (0)1372 370977, E-mail: cpd.uk@intertek.com

0359-CPR-00438 Issue 1

www.intertek.com

Registered No 3272281 Academy Place, 1-9 Brook Street, Brentwood, Essex, CM14 5NQ, United Kingdom